
**Instruction
Manual**

HR1300

Model 3750
Portable
Hybrid Recorder

IM 3750 - 01E
















How to use this Instruction Manual

This Instruction Manual describes the standard functions and operation procedures of Model 3750, HR1300 recorder. For operation methods of other options, see other instruction manuals listed below.

<u>Product name</u>	<u>Model</u>	<u>Instruction Manual No.</u>
GP-IB interface	/GP-IB	IM 3750-50E
RS232C interface	/RS232C	IM 3750-50E
Calculation function	/MATH	IM 3750-60E
User's linearization and Remote RJC	/ULN	IM 3750-70E
DC power source	/DC	IM 3750-70E
AC input (AC voltage 1 point, AC current 1 point)	/AC2	IM 3750-70E
AC input (AC voltage 3 points, AC current 3 points)	/AC6	IM 3750-70E

CONTENTS

1. INSTRUMENT INSPECTION	1-1	1
1.1 Accessories and External Visual Check	1-1	2
1.2 Model Number and Specification Verification	1-3	3
1.2.1 Model Number Verification	1-3	4
1.3 Preparations Prior to Use	1-5	5
1.4 Self-Test	1-7	6
2. GENERAL	2-1	6.1
2.1 Product Outline	2-1	6.2
2.2 Features	2-2	6.3
2.3 Recording Examples	2-4	6.4
3. COMPONENT NAMES AND FUNCTIONS	3-1	6.5
3.1 Component Names and Functions	3-1	6.6
3.2 Recorder Main Unit DIP Switches	3-2	6.7
4. INSTALLATION	4-1	6.8
4.1 Installation Site	4-1	6.9
4.2 Mounting (Rack Mount)	4-2	6.10
5. CONNECTIONS	5-1	6.11
5.1 Wiring	5-1	6.12
5.1.1 Power Wiring	5-1	7
5.1.2 Input Wiring	5-1	8
5.2 Terminal Arrangement	5-3	9
5.3 Wiring to Input Terminals	5-4	10
6. OPERATION	6-1	11
6.1 Chart and Ribbon Installation	6-1	12
6.1.1 Chart Installation and Replacement	6-1	13
6.1.2 Ribbon Cassette Installation and Replacement	6-4	
6.2 Description of Initial Settings	6-7	
6.3 Simple Example of Entering Data	6-8	
6.3.1 Example of Changing Setting to Thermocouple (TC)	6-8	
6.3.2 Error Code Summary Table	6-11	
DESCRIPTION OF BASIC FUNCTION, OPERATION, AND SETTING	6-14	
6.4 Panel Operation Description	6-14	
6.4.1 Names and Functions of Individual Keys	6-14	
(1) [Recording-Related Keys]	6-14	
① Recording START/STOP Key	6-15	
② HEADER Key	6-15	
③ LIST Key	6-15	

④ MAN PRINT Key	6-15
⑤ CHART FEED Key	6-15
⑥ KEY LOCK Key	6-15
(2) [Display-Related Keys]	6-16
⑦ UPPER DISPLAY Changes	6-16
⑧ LOWER DISPLAY Changes	6-16
⑨ Function Keys (F1 through F4)	6-18
⑩ NEXT Key (NEXT)	6-18
(3) [Alarm Display and Alarm Output Relay Related Keys]	6-19
⑪ ALARM ACK Key	6-19
⑫ ALARM RESET Key	6-19
(4) [Setting Entry Related Keys]	6-20
⑬ ENTRY Key ()	6-20
⑭ Numeric Key (Including  and  Keys)	6-20
⑮  ,  ,  ,  Keys (Cursor Movement, Screen Forward/Back Shift)	6-21
⑯ Channel Change Keys ( ,  ,  Keys)	6-21
⑰ RANGE Setting Key ( Key)	6-21
⑱ ALARM Setting Key ( Key)	6-21
⑲ AUX Function Setting Key ( Key)	6-21
⑳ CHART SPEED Setting Key ( Key)	6-22
㉑ LOCAL Key ( Key)	6-22
㉒ MEMORY Key	6-22
㉓ FUNC Key	6-22
6.4.2 Other Displays	6-23
㉔ TREND, LOG, REMOTE, CHART, MAIN BAT and CARD BAT ..	6-23
㉕ FAIL	6-23
6.5 Setting Flowchart	6-24
6.5.1 Setting Flow (Page number)	6-24
6.5.2 Setting Information Summary (RANGE, ALARM and AUX Keys)	6-28
6.6 Channel Number Specification (Group Specification)	6-30
6.7 Range Setting	6-31
6.7.1 Voltage (VOLT) Measurement Setting	6-34
6.7.2 Thermocouple (TC) Measurement Setting	6-35
6.7.3 Resistance Temperature Detector (RTD) Measurement Setting	6-36
6.7.4 Setting for Recording Operations Using Contact Input (DI)	6-38
6.7.5 Difference Computation Setting	6-39
6.7.6 Scaling Setting (with Unit Assignment Capability)	6-41
6.7.7 Skip Setting	6-43
6.8 Alarm Setting	6-45
6.9 Chart Speed Setting	6-49

6.10 Settings Under AUX	6-51
(Usually, the initial value has been set, but items which may be changed) during measurement upon user's request are summarized herein.	
6.10.1 CLOCK Setting	6-52
6.10.2 SYSTEM Setting	6-53
(1) FORMAT Selection	6-53
(2) Recording Mode Selection	6-53
(3) Trend Recording Mode Selection	6-54
6.10.3 PRINT FORMAT Setting (Individual Channel Recording ON/OFF)	6-55
(1) TREND Recording ON/OFF Specification	6-55
(2) DIGITAL Recording ON/OFF Specification	6-55
(3) LOGGING INTERVAL Specification	6-56
6.10.4 Tag Settings	6-57
6.10.5 MESSAGE Setting	6-58
6.10.6 HEADER Setting	6-60
6.10.7 ZONE Recording Setting (Recording width Setting)	6-62
6.10.8 PARTIAL Compression Recording Setting	6-64
6.10.9 LOGGING INTERVAL Setting (Including Start Time)	6-67
6.10.10 Setting of Chart Speed and Logging Interval Used	
When Change-On-Alarm or Remote Control in Effect	6-70
6.10.11 Interpolation Setting	6-71
6.10.12 Moving Average Setting	6-72
6.11 Changing SET UP (Basic Pre-Use Recorder Specifications)	6-74
(* Although the SET UP parameters normally do not require change, you may need to refer to this section when adding options or modifying functions to fit an application. * These parameters cannot be changed during operation.	
6.11.1 Recording Related SET UP (RECORD)	6-80
(1) Channel Printing, Tag Printing Selections	6-80
(2) Scale Printing Selection	6-80
(3) Selection of Number of DIGITAL Recording Columns for TREND Recording	6-82
(4) CHANNEL Number Printing Pitch Selection	6-82
(5) TITLE Printing Spacing Selection	6-82
(6) Vertical/Horizontal Recording Direction Selection for Logging Recording	6-83
(7) Speed Printout on Chart Speed Change	6-83
(8) Marking Recording Selection	6-83
(9) Partial Compression Recording Selection	6-84
(10) Alarm Print ON/OFF Selection	6-84
(11) TIC (SCALE Printout Position) PRINT ON/OFF	6-84
(12) Handling When Internal Computation Reaches Maximum Value	6-85
(13) Selection of Printout for Computation (MATH Option)Error	6-85
6.11.2 INTERVAL Related SET UP (INTVL)	6-86
(1) SCAN INTERVAL Selection (2 to 60 Seconds)	6-86
(2) Logging Interval Mode Selection	6-87

6.11.3	Alarm, Communications, IC Memory Card and Remote Control Related SET UP (CONTROL)	6-88
(1)	Selection for Reflash on New Alarms	6-88
(2)	ALARM Relay Output AND/OR Selection	6-89
(3)	Internal ALARM Relay Output Energize/De-Energize Selection	6-90
(4)	Recording Start/Stop Control and Internal (Alarm) or External (Remote Control Option) Command Format (Trigger or Level) Selection	6-90
(5)	Selection of Whether to Perform Change On (Chart Speed Interval Change) and/or Print ON (Recording ON/OFF) with External Remote Control or with Alarms	6-91
(6)	Front Panel ALARM ACK Key Enable/Disable Selection	6-91
(7)	ALARM Relay Output Hold/Non-Hold Selection	6-92
(8)	Scan Interval Selection for Rate of Change (RH, RL) Settings	6-93
(9)	ALARM Hysteresis Selection (For High (H) and Low (L) Limit Alarms)	6-93
(10)	Digital Recording Control Selection	6-94
(11)	Communications Input (31 to 60) ON/OFF	6-94
(12)	IC Memory Card Input (31 to 60) ON/OFF	6-94
6.11.4	Key Lockout SET UP	6-95
6.11.5	Burnout Related SET UP (BURN)	6-97
6.11.6	Group SET UP	6-98
6.11.7	Logic SET UP (Set mainframe operation during print-on/change-on alarm activation)	6-99
6.11.8	RJC SET UP	6-101
6.11.9	Recording Color SET UP (COLOR)	6-102
6.11.10	°C/°F Temperature Display SET UP	6-103
6.12	Function Call (FUNC) SET UP	6-104
7.	IC MEMORY CARD	7-1
7.1	Outline	7-1
7.1.1	Background	7-1
7.1.2	Specifications	7-2
7.1.3	Battery Installation/Replacement	7-3
7.1.4	Introduction to the Setting Screen	7-4
7.1.5	Initialization	7-5
7.1.6	Background Information to Know Before Setting	7-7
7.1.7	Storing Setting Information (SET)	7-8
7.1.8	Measured Data Storage	7-11
8.	CONTACT OUTPUTS AND INPUTS	8-1
8.1	Remote Control Function (Option /REM) Specifications	8-2
8.2	Internal Alarm Output Relays (Option /AK-02)	8-4
9.	MAINTENANCE (FUSE REPLACEMENT)	9-1

10. ACCESSORY MODEL NAMES AND PART NUMBERS	10-1
11. RECORDER SPECIFICATIONS	11-1
12. PRINTOUT ADJUSTMENT	12-1
13. SCHEMATIC DIAGRAMS AND PARTS LIST	13-1
CUSTOMER MAINTENANCE PARTS LIST	CMPL 3750-01E

	1. INSTRUMENT INSPECTION	1-1
1	2. GENERAL	2-1
2	3. COMPONENT NAMES AND FUNCTIONS	3-1
3	4. INSTALLATION	4-1
4	5. CONNECTIONS	5-1
5	6. OPERATION	6-1
6	6.1 Chart and Ribbon Installation	6-1
6.1	6.2 Description of Initial Values	6-7
6.2	6.3 Simple Setting Entry Example	6-8
6.3	DESCRIPTION OF BASIC FUNCTION, OPERATION, SETTING	6-14
6.4	6.4 Operation Panel Description	6-14
6.5	6.5 Setting Flowchart	6-24
6.6	6.6 Channel Number Specification (Group Specification)	6-30
6.7	6.7 Range Setting	6-31
6.8	6.8 Alarm Setting	6-45
6.9	6.9 Chart Speed Setting	6-49
6.10	6.10 Settings Under AUX	6-51
6.11	6.11 Changing SET UP (Basic Pre-Use Recorder Specifications)	6-74
6.12	6.12 Function Call (FUNC) SET UP	6-104
7	7. IC MEMORY CARD	7-1
8	8. MAINTENANCE (FUSE REPLACEMENT)	8-1
9	9. CONTACT OUTPUTS AND INPUTS	9-1
10	10. ACCESSORY MODEL NAMES AND PART NUMBERS	10-1
11	11. RECORDER SPECIFICATIONS	11-1
12	12. PRINTOUT ADJUSTMENT	12-1
13	13. SCHEMATIC DIAGRAMS AND CUSTOMER'S PARTS LIST	13-1

1. INSTRUMENT INSPECTION

1

Although this instrument has been thoroughly inspected at the factory before shipment, you should check the following points when it is delivered to you.

1.1 Accessories and External Visual Check

The HR1300 is supplied with those accessory items shown in Figure 1.2 and Table 1.1. Please verify that none are missing. You should also check the instrument exterior to ensure that there has been no damage (see Figure 1.1).

If any accessories are missing, or there are any problems such as external damage, please contact your agent.

<HR1300 / 3750>




Figure 1.1 External Appearance Drawing

(1) Accessories for the HR1300


1

Figure 1.2 HR1300 Accessories

Table 1.1 HR1300 Accessory Table

Number	Name	Part No.	Quantity	Remarks
1	Ribbon cassette	B9627AZ	1	
2	Fuse	A9197KF	1	1.25 A time-lag type (in fuse holder)
3	Instruction manual	—	1	IM 3750-01E
4	Chart paper	B9855AY	1	
5	Power cord	A9009WD	1	Rated voltage 125V, standards other than below
6	Power cord	A9008WD	1	UL standard, rated voltage 125V
7	Power cord	A9011WD	1	VDE standard, rated voltage 250V
8	Power cord	A9026WD	1	SAA standard, rated voltage 240V
9	Connector	A9026KC	1	36 - pin connector

Select

1.2 Model Number and Specification Verification

1.2.1 Model Number Verification

As shown in Figure 1.3, the Model Number and other information about the HR1300 Hybrid Recorder are inscribed on a name plate on the left side of the case.

Verify that the instrument received conforms exactly to the order specifications.

Please indicate the model number and serial number in any communications with us.

Opening the door and removing the chart cassette will enable you to check the name plate. See Section 1.3, "Preparations Prior to Use", for the chart cassette removal procedure.




Figure 1.3 Model Number Verification

Model and Suffix Codes

Mode	Suffix Codes		Optional Code	Description
HR1300	3750	12	10 points/2 sec (high-breakdown-voltage solid-state relay)
		22	20 points/2 sec (high-breakdown-voltage solid-state relay)
Power requirements		- 0		90 to 250V AC
Frequency		1	50 Hz
		2	60 Hz
Optional features			/ <input type="checkbox"/>	Should be specified at the time of order

Optional Features

Option Code	Description	
/ GP-IB	GP-IB interface	Not mixed
/ RS232C	RS-232C interface	
/ MATH	Mathematical functions	
/ REM	Remote control	
/ AK-02	Alarms (internal, 2 points)	
/ SIT	Screw input terminal block	
/ DF	°F display	
/ DC	DC power source	
/ AC2	AC input (2 points)	Not mixed
/ AC6	AC input (6 points)	
/ ULN	User's linearization	

Optional Accessories

Code	Name
3789 03	IC Memory card, 64K bytes
3789 04	IC Memory card, 256K bytes
3789 05	IC Memory card, 512K bytes
3798 11	Rack mounting kit for HR1300 (JIS)
3798 13	Rack mounting kit for HR1300 (ANSI)
3798 01	Clamped input terminal block (10 points)
3798 02	Screw input terminal block (10 points)
4389 20	Shunt resistor
4389 21	(For clamped input terminal block)
4389 22	
4159 20	Shunt resistor
4159 21	(For screw input terminal block)
4159 22	

Spares

Part No.	Name	Unit for Sales
B9627AZ	ten-color ink ribbon	1
B9855AY	Z-fold chart (20m), 10mm div. on time axis	6

1.3 Preparations Prior to Use

Remove the soft cover from the recorder, take the recorder out of its packing, and remove the clamp plate which holds the carriage section during shipment to prevent damage.

CAUTION

Damage to the recorder may result if power is applied without removing the clamp plate. Make absolutely sure that you have removed the clamp plate from the carriage section before you turn on the power.

- (1) Opening the door exposes the "stopper" latches on each side at the bottom of the chart cassette (see Figure 1.4).
- (2) When the two stopper latches are pressed down, the chart cassette will swing out toward you.




Figure 1.4

- (3) Lift the chart cassette gently and pull it towards you to separate it from the main unit (see Figure 1.6).




Figure 1.5

- (4) A screw that fastens the clamp plate is at the top left inside the internal assembly (Figure 1.6).
- (5) As shown in Figure 1.6, loosening the locking screw by turning it in the direction of the arrow and pushing the clamp plate down and away from the carriage will enable the carriage to move freely.




Figure 1.6

- (6) Keeping the clamp plate in the lowered position, retighten the locking screw to secure the clamp plate.

1.4 Self-Test

Before final installation in a rack, it is necessary to check whether there has been any damage to major components of the recorder due to shipping. A self-test program is provided in the recorder to test the major components for this purpose. Turning on the power initiates these tests automatically.

Determine from the results of these tests whether there has been any damage to major components.

<Self-Test Procedure>

- (1) First verify that the recorder power switch is turned OFF, then connect the power cord to the rear panel power connector as shown in Figure 1.7, and connect the power cord plug to a power outlet.




Figure 1.7

- (2) Turn on the power switch (see Figure 1.8).





Figure 1.8

- (3) A display will appear as shown here to indicate that self-test is in progress. Although a FAIL indication will appear at first, it does not indicate a malfunction.



(4) Self-Test Results

1) If Normal—

The print carriage will move to the home position on the left side (as seen from the front). If the carriage is already in the home position when power is turned ON, it will first move a few mm to the right and then return to the home position. While this is occurring, the display will indicate a DATA AUTO status.

2) If Not Normal—

If the test finds a problem, it will stop and display one of the following error messages:

- ROM error "ROM ERROR"
- RAM error "RAM ERROR"
- A/D calibration value error "A/D ILLEGAL ADJUST" or "A/D SUM ERROR"
- Printer card error "PRINTER FAIL"
- General-purpose communications card error
..... "COMM CARD ERROR"
- General-purpose communications disconnected
..... "COMM CARD REMOVED"

CAUTION

If an error message is displayed, the recorder will not operate properly. Immediately turn off the power and contact your agent or our nearest service facility.

When contacting your agent or our service department, please give the model number, serial number, and the error message displayed, as this will help reduce the time required for the service person to repair the unit.

(5) Cautions about Noise


Hybrid recorder has 3 modes.

- 50Hz (20m sec integration)
- 60Hz (16.7m sec integration)
- 100m sec integration


Set by Dip switches. See page P3-3.

Examples of each is shown below.


① The case of 50Hz (20m sec integration)



② The case of 60Hz (16.7m sec integration)



③ The case of 100m sec integration



For applications of mixed frequency (i.e. 50Hz and 60Hz), measurement can be done using 100msec integration time.

100msec integration mode has the following restrictions concerning scan interval.

The Fastest SCAN Interval

50Hz or 60Hz	100m sec integration
2 sec	6 sec

- ④ Grounding the recorder and measuring object can greatly decrease common mode noise.

2. GENERAL

2

2.1 Product Outline

The HR1300 is a state-of-the-art advanced-function microprocessor-based hybrid recorder developed to bring together new features requested by our users, while retaining those qualities of earlier Yokogawa models which have proven YOKOGAWA to be the pioneer in hybrid recorders. This instrument has a large number of functions which merits its appellation as a third-generation hybrid recorder.

- High-speed Scanning : 20 points/2 seconds (high-breakdown-voltage solid-state relays)
- High-speed Recording : 50 points/2 seconds
Gives an analog recording of 30 computed data points in addition to 20 measurement data points
- 10-color Recording : Programmable 10-color recording
- Simple Interactive Operation System with Large Multi-Element Display
- IC Memory Card : Permits saving and recalling of measured data, computed data, and parameter settings.
- Variety of Computational Functions (Optional) Including Arithmetic and Statistical Computations
- Variety of Alarms (including /AK-02)
- Computer-friendly (with GP-IB, RS-232C options)
- AC input (option)
- DC power (option)

These capabilities make it the last word in hybrid recorders.

We hope that you will find this recorder useful as a multi-purpose instrument for efficiently performing data acquisition, recording, monitoring and control in process industries, research and development, or test and inspection departments.

2.2 Features

2

- **High-speed Scanning** : 20 points/2 seconds

- **High-speed Recording** : 50 points/2 seconds

Through improvements to the raster scan system and the wire dot printer proven on earlier models, the recorder can scan up to 20 data points in two seconds and, including computed data, can record up to 50 points in two seconds. This substantially improves the simultaneity of the data and enables more dependable data analysis.

- **10-color Recording**

Addition of four new colors—orange, yellow-green, dark blue, magenta—to the existing purple, red, green, blue, brown and black makes for even easier-to-read analog recordings.

- **Small Size and Lightweight**

- **Easy Operation with Interactive Format**

Setting is simplified through an interactive format, and the ribbon and chart can be replaced in a quick "3-touch" procedure.

Input terminal blocks can be removed when connecting wiring, enabling connections to be made securely in an accessible position.

- **IC Memory Cards**

IC memory cards with up to a 512K-byte capacity can be used, enabling storage and retrieval of measurement data, computed data, and parameter settings. Events such as alarms, chart end, and external contacts can be used to trigger acquisition of data in IC memory, so there is no loss of data.

- **Abundant Computing Functions (optional)**

The following computing functions are provided for a significantly enhanced efficiency in data analysis; four-function arithmetic, square root, absolute value, common logarithm, exponential, maximum and minimum value, average, total, maximum minus minimum, standard deviation, and deviation.

- **Rich Variety of Input**

DC voltage, thermocouple, resistance temperature detector, or contact input can be freely selected for each individual input. DC current is also available with a shunt resistor.

- **Many Recording Variations**

Analog record, analog/digital record, and logging record are available as recording formats, so that the format can be matched to the application objectives. Moreover, you can record with a wealth of variations by using functions such as zone recording, partial compression, titles, scaling, and tag number printing.


- **Full Complement of Alarm Functions**

The recorder provides an abundance of alarm functions such as upper and lower limit alarms, the difference (ΔT) between upper and lower limit alarms, and rate-of-change alarms, and allows you to freely combine them to set up to six levels per channel. These display their power across a broad range of applications such as process and production line control.

- **Large, Easy-to-read Multi-Element Display**
- **Free Scaling Function and Difference (ΔT) Computation Function**




- **Options and Accessories**

Options include remote control, an internal alarm output unit (2 points), GP-IB interface, RS-232C interface, IC memory card, DC power source, AC input and user's linearization.





(PRINT ON)

When **START/STOP** is pressed, the words PRINT ON will be printed in the upper-right hand corner of the chart.

1. Normal PRINT ON**2. "PRINT ON" will print out immediately after turning ON the power.****3. "PRINT ON" will print out when chart speed (mm/h) × trend recording interval (sec.) is more than 3000:****(Alarm printout)**

When an alarm occurs or is canceled, the alarm contents are printed out in the upper-right hand corner of the chart.

1. Alarm printout in CH print mode:**2. Alarm printout in TAG print mode:**

※ To change TAG mode to CH mode or vice versa, set SET UP mode first.

3. When chart speed (mm/h) \times trend recording interval (sec.) is more than 3000:
alarm printout is not executed.

Note: * Alarm data overflow

* If "*" (alarm data overflow) is printed, some alarm messages are missing (not printed). Alarm occurrence and canceling (up to 50 data) can be stored in memory and printed in sequence; however, if alarms occur and are canceled many times, alarm printout (output from memory) speed is slower than alarm occurrence and canceling (input to memory), and so memory overflows. Therefore, some overflow alarm data will be neither stored nor printed.

(Time printout)

1. Single mode

Time intervals are selected according to the chart speed and printed.

20	0.0000V
19	0.0000V
18	0.0000V
17	0.0000V
16	0.0000V
15	0.0000V
14	0.0000V
13	0.0000V
12	0.0001V
11	0.0001V
10	-0.1786V
09	1.3539V
08	1.3540V
07	1.3541V
06	1.3542V
05	1.3542V
04	1.3543V
03	H 1.3544V
02	1.3545V
01	1.3546V

Measured data

100mm/h ← Chart speed

Jun. 01 01:00

month day time ← Time printout position

Chart Speed	Measured Data Recording Intervals	
	1-row	2-row
10 to 24mm/h	12 hours	6 hours
25 to 49 mm/h	4 hours	2 hours
50 to 99 mm/h	2 hours	1 hour
100 to 500 mm/h	1 hour	30 minutes


For chart speeds other than the above, the measured data recording intervals are not printed. If chart speed (mm/H) \times trend recording interval (sec.) is more than 3000, the measured data recording intervals are not printed either.

2. MULTIPLE mode


The time is printed in the upper-right hand corner of the chart depending on the chart speed.

Chart Speed (mm/h)	Time-printout Intervals
100 to 1500	Every hour
50 to 99	Every two hours
25 to 49	Every four hours
10 to 24	Every twelve hours
up to 9	No printout

2.1 Time printout when chart speed (mm/h) \times trend recording interval (sec.) is less than or equal to 3000:



2.2 Time printout when chart speed (mm/h) \times trend recording interval (sec.) is more than 3000:




(CHANGE ON printout)

If the chart speed is changed, a new chart speed is displayed in the upper-right hand corner of the chart.


It is not possible to record the comment.

IF PRINT ON MODE is set, CHANGE ON printout is not performed.

1. When chart speed (mm/h) \times trend recording interval (sec.) is less than or equal to 3000, CHANGE ON is printed.




2. CHANGE ON printout when chart speed (mm/h) \times trend recording interval (sec.) is more than 3000:



(Message printout)

Entered messages are printed. The message printout position changes with TAG/CH and the line numbers in the logging mode.

1. Message printout when chart speed (mm/h) \times trend recording interval (sec.) is less than or equal to 3000:



2. Message printout when chart speed (mm/h) \times trend recording interval (sec.) is more than or equal to 3000:

No messages are printed.

Note : Message overflow

Up to 12 message data can be stored in memory. If message printout requests continue, message printout speed (output from memory) will be slower than message printout requests (input to memory), thereby overflowing the memory. So, overflow printout data are neither stored nor printed.

3. COMPONENT NAMES AND FUNCTIONS

3.1 Component Names and Functions

3

HR1300




Figure 3.1 HR1300 Component Names

- ① Power Switch
Turns on and off power supplied to the recorder.
- ② Display Panel
- ③ Setting Panel
See Section 6.4 for operating instructions.
- ④ IC Memory Card Drive
IC memory cards are inserted into this drive port for use.
- ⑤ Chart and Chart Cassette
The recorder uses a Z-fold chart, 20 m (66 feet) in length, with an effective analog trend recording width of 150 mm (10 inches nominally). The chart is stored inside a chart cassette.

3.2 Recorder Main Unit DIP Switches

The DIP switches are located on the rear of the recorder (see Figure 3.2). The DIP switch functions are as follows:

3




Figure 3.2 DIP Switch Setting

- | | | | |
|-------|---|---|---|
| No. 1 | : | ON to enable SET UP parameter changes. | (Upon shipment) |
| No. 2 | : | ON to select 100 msec integration (for both 50 and 60Hz operation).
When ON, minimum measurement interval becomes 6 seconds.
Set to OFF if noise is a problem.
Please see P1-11. | OFF |
| No. 3 | : | 50/60Hz selection
When ON : 20 msec integration (50Hz)
When OFF: 16.7 msec integration (60Hz) | As specified |
| No. 4 | : | ON to enable writing to IC memory card.
OFF to disable writing to IC memory card.
(Reading is always enabled.) | ON |
| No. 5 | : | } Always OFF | OFF |
| No. 6 | : | | OFF |
| No. 7 | : | | OFF |
| No. 8 | : | | ON to enable A/D calibration, etc. This switch OFF is for use at time of shipment and during adjustment by service personnel. Use by the customer will cause incorrect operation. Please leave these switches OFF at all times. |

Make changes in the DIP switch with the power OFF.

4. INSTALLATION

4.1 Installation Site

The recorder installation site should be chosen so as to meet the following conditions as much as possible:

4

- (1) Minimal mechanical vibration.
- (2) Minimal presence of corrosive gases.
- (3) Near room temperature (23°C) with minimal temperature fluctuations.
- (4) Not directly exposed to high heat radiation.
- (5) Minimal electromagnetic field influence.
- (6) Humidity neither too high nor too low ;
keeping it constant at 55% is ideal.

4.2 Mounting (Rack Mount)

(1) HR1300 Rack Mounting

- 1) The optional rack adapter (3798 11 or 3798 13) should be used for rack mounting.
When mounting the recorder on a rack, attach blind patches on top and bottom of the recorder.
- 2) Before mounting the recorder in a rack, protect the internal assembly by returning the clamp plate removed in Section 1.3 back to its original position, thus locking the carriage in place.
- 3) Figure 4.1 shows the external dimensions and rack mounting dimensions for the HR1300.

Dimensions

Unit : mm
(inch)




Figure 4.1 HR1300 External Dimensions and Rack Mounting

- 4) When you have finished the rack mounting, take off the clamp plate from the carriage as described in Section 1.3 (P1 - 6).

5. CONNECTIONS

5.1 Wiring

5.1.1 Power Wiring

For AC Power

Turn off the recorder power switch and connect the power cord supplied with the recorder to the recorder power connector on the rear panel as shown in Figure 5.3. For safety, connect the ground terminal to a ground of Class 3 or better.

5

5.1.2 Input Wiring

- (1) For the best thermocouple input wiring, it is recommended that the thermocouple element conductors be directly connected to the recorder input terminal.

However, for wiring over a considerable distance between the recorder and measuring point, a thermocouple extender wire is generally used.

- (2) Connections to the recorder input terminals should be made as follows:

- 1) For a clamped input terminal model:
strip about 6mm (1/4inch) of insulation from the end of the wire, insert it into the input terminal, and tighten the screw (Figure 5.1).
- 2) For a screw input terminal model:
available by specifying the /SIT option: use insulated sleeve crimp-on terminals (for 4mm screws) such as those shown in Figure 5.2.1 for leadwire terminations (Figure 5.2.2).




Figure 5.1 Clamped Input Terminal Type)




Figure 5.2.1




Figure 5.2.2 Screw Input terminal Type)

- (3) Adhere to the following requisites so as to prevent noise produced in the measurement circuit:
- 1) Keep wiring to the recorder input terminals separate from the power and ground circuits.
 - 2) Use of a shielded cable for wiring to the recorder input terminals is effective against noise due to electrostatic induction. Connect the shield to the recorder ground terminal.
 - 3) To reduce noise due to electromagnetic induction, it is comparatively effective to use wires twisted at a constant pitch for wiring to the recorder input terminals.

CAUTION

5

1. The maximum permissible input voltage at the input terminals is 60V DC peak, with a maximum permissible common-mode voltage of 250V AC. Take care not to apply excessive voltages. Also, exercise caution so that over-voltages are not applied due to static electricity or other causes when wiring is being connected.
2. After connecting the wiring, be sure to replace the terminal cover, both for safety and to obtain the rated measurement accuracy. Be particularly careful in the case of thermocouple input, as operation without the cover may cause measurement errors or fluctuations.

5.2 Terminal Arrangement

Recorder Rear Panel




Figure 5.3 Terminal Arrangement(Clamped Input Terminal Model)




Figure 5.4 Clamped Input Terminal Arrangement




Figure 5.5 Screw Input Terminal Arrangement

5.3 Wiring to Input Terminals

Connect the leadwires to the recorder input terminals as shown in Figures 5.6 and 5.7.

Clamped Input Terminal Model




Figure 5.6

Screw Input Terminal Model




Figure 5.7

6. OPERATION

6.1 Chart and Ribbon Installation

6.1.1 Chart Installation and Replacement

(1) Chart Installation

The chart can be installed or replaced with power either OFF or ON.

- 1) To ensure a proper chart-feed, riffle and fan the chart on both ends (see Figure 6.1.1).
- 2) Open the front door and remove the chart cassette from the recorder (see Figures 1.4 and 1.5 on pages 1-5, 1-6).
- 3) Remove the chart pressure roller. A spring mechanism is built into the left end of the roller. Push the roller to the left and remove it (see Figure 6.1.2).

6
6.1




Figure 6.1.1




Figure 6.1.2

- 4) Lift the knobs on the left and right sides of the chart pressure plate at the rear of the chart cassette, and slide the plate back (see Figure 6.1.3).
- 5) Place the chart in the storage compartment with the round drive holes of the paper on the left and the chart-cut end pointing toward you (see Figure 6.1.4).

6

6.1




Figure 6.1.3




Figure 6.1.4

- 6) To engage the chart drive holes with the sprockets correctly, install the chart paper so that the mark "." [A in Figure 6.1.5] appearing every 5 cm meets a groove [B in Figure 6.1.5].
- 7) Return the chart roller and chart pressure plate to their original positions, following ① through ③ in Figure 6.1.6. Engage the projections ③, indicated by the arrow (see Figure 6.1.6) with the holes on the left and right sideplates on the chart cassette.




Figure 6.1.5




Figure 6.1.6

- 8) Engage the projections on the chart cassette with the support mechanism on the recorder chassis, and insert the cassette into the support mechanism completely (see Figures 6.1.7 ① and 6.1.8 ①).
- 9) Swing and push the chart cassette into the recorder chassis until it locks with a click (see Figures 6.1.7 ② and 6.1.8 ②).
- 10) With the power turned on, press the FEED button on the front left side of the recorder to feed out at least three folds of chart paper to the receiver, and verify that the chart is feeding properly. Note that you should also press the FEED button to verify operation after manual feeding of a blank chart.
If the chart is not feeding properly, repeat the procedure starting from step 2).
- 11) When the chart end is near, the message, "RENEW CHART", printed in scarlet will appear in the chart margins to notify you that it is time to ready a new chart.
- 12) The CHART indicator on the front left side of the recorder will light when the chart reaches its end. Replace it with a new chart according to the above procedure steps 1) through 10).




Figure 6.1.7




Figure 6.1.8

(2) Chart Replacement

- 1) When "CHART" appears on the display, prepare a new chart for replacement.
- 2) Press the **START/STOP** key to stop the recording (scanning will continue).
- 3) Put in a new chart following the "(1) Chart Installation" procedure.

CAUTION

Please use only genuine Yokogawa chart paper, B9855AY.
Using charts other than those specified may cause problems.

6.1.2 Ribbon Cassette Installation and Replacement

(1) Ribbon Cassette Installation

Note 1: Before using the recorder for the first time, make sure that the shipping stop (clamp plate) has been released (See Figure 1.6).

Note 2: Do not allow the printing mechanism to operate without a cassette ribbon installed. Operation without a ribbon may damage the platen and/or tear the chart.

- 1) Open the front door and remove the chart cassette (Figure 6.1.9).
For chart cassette removal, see pages 1-5 and 1-6.




Figure 6.1.9

- 2) Pressing the red lever on the carriage (Figure 6.1.10) will move the ribbon cassette holder to the right (See Figure 6.1.11).




Figure 6.1.10 Carriage




Figure 6.1.11

- 3) Tilt the ribbon cassette holder in the direction of the arrow (Figure 6.1.9).
- 4) Rotate the shaft on the ribbon cassette counterclockwise to take up any slack in the ribbon (Figure 6.1.13).




Figure 6.1.12




Figure 6.1.13 Ribbon Cassette

- 5) Insert the ribbon cassette into the holder (Figure 6.1.14), and return it to a horizontal position (Figure 6.1.15).
- 6) Raise the ribbon cassette front and return to level (Figure 6.1.15).




Figure 6.1.14




Figure 6.1.15

- 7) Push the ribbon cassette to the left until it reaches the stopper (Figure 6.1.16). Confirm that the 3 white lines on the head cover are completely hidden from view when viewed from the front. If the white lines can be seen, the ribbon cassette is not installed properly. Push the ribbon cassette to the left once more (Figure 6.1.17, 6.1.18).





Figure 6.1.16



White lines visible = Incorrect

White lines hidden = Correct

Figure 6.1.17

Figure 6.1.18

- 8) Turn the ribbon cassette knob counterclockwise to tighten the ribbon (Figure 6.1.13).
 9) Return the chart cassette to the recorder. This completes ribbon cassette installation. Push FEED KEY once after ribbon cassette installation. Not pushing FEED KEY, chart start will be later than setting.

Make sure that the ribbon cassette is securely fastened to the carriage, and that the ribbon is properly positioned on the print head.

If you use same ribbon cassette for long time, the ribbon will be waved. It cause no printout by gap between ribbon and printer head. Exchange the ribbon at this case.

(2) Ribbon Cassette Replacement

- 1) When replacing the ribbon cassette, first press the START/STOP key to stop the printer function.
- 2) Install the new ribbon cassette in the carriage according to the foregoing "(1) Ribbon Cassette Installation" procedure.

6.2 Description of Initial Settings

Initial Settings

- Measurement Range 2V range (All channels)
Measurement span -2.0000V to $+2.0000\text{V}$
Scaling OFF
- Measurement Interval 1scan / 2 seconds
- Recording Format Trend record (Analog+digital)
- Trend Interval AUTO mode (Recording interval determined by chart speed.)
- Logging Interval SINGLE mode (Recording interval : 1 hour)
- Recording Zone 0 to 150 mm
- Chart Speed 100 mm/H
- Display UPPER DISPLAY : Data auto-display
LOWER DISPLAY : Data auto-display
- Alarms All levels OFF on all channels
- TAG, MESSAGE, HEADER . All channels and all items set to spaces


6.2

6.3 Simple Example of Entering Data

6.3.1 Example of Changing Setting to Thermocouple (TC)

This section explains the procedure for changing the following setting parameters, assuming that the recorder is in the initial condition described in Section 6.2.

Channel : Channel 2
 Range : Thermocouple type T
 Temperature range -200.0°C to 400.0°C
 Alarms : High-limit alarm set at 100°C
 Recording : Analog recording range (recording zone) set at 0 to 100 mm



6.3

[Range] [Channel]

[Key Entry, Panel Display] The panel displayed when * key is pressed.

[Description]

Key entry: **RANGE** , * **CH UP** Δ , **ENTRY**

02:MODE=VOLT

↓SKIP VOLT TC RTD

- Go into range setting mode and select Channel 2.

Key entry: * **F3** , **ENTRY**

02:MODE=TC

↓SKIP VOLT TC RTD

- The TC (thermocouple) setting screen appears.

Key entry: **NEXT** , * **F3** , **ENTRY**

02:RANGE=TYPE-T

↓E J T N

- Select type T.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: , , , , ,

02:SPAN L=-200.0°C

▶ T RNG -200.0~400.0°C

- Left input span value of -200.0 °C.

Key entry: , , , , ,

02:SPAN R= 400.0°C

▶ T RNG -200.0~400.0°C

- Right input span value of 400.0 °C.

*** SET OK ***

02:TYPE-T -200.0~400.0°C

- Range setting complete.

6.3

[Alarm] The panel displayed when * key is pressed.

Key entry: , ,

02:LEVEL=1

↓1 2 3 4

↓5 6

- Set alarm.
Although up to six levels can be set for each channel, here we will select only one.

Key entry: ,

02/1:ALARM=ON

ON OFF

- Turn ON the Level 1 alarm of Channel 2.

Key entry: ,

02/1:TYPE=H

H L RH RL

- Select upper-limit alarm (H).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: , , , , , ,

02/1: VAL=100.0°C

▶ ALARM RNG -200.0~400.0°C

Key entry: ,

02/1: RELAY=OFF

ON OFF

- Set upper-limit alarm value to 100.0 °C.

- If you will not use a relay output, set this to OFF.

*** SET OK ***

02/1 ON H 100.0°C

- Alarm setting is complete.

[Recording Zone] The panel displayed when * key is pressed.

Key entry: , , ,

AUX MODE=ZONE

↓ MSG HEADER ZONE PART

- Set recording zone.

Key entry: , , , ,
,

02: ZONE=0~100mm

▶ Zone left: 0~145mm

- Set the recording zone (left) to 0 and recording zone (right) to 100 mm.
- Left zone ranges 0 to 145 mm.
- Right zone ranges 5 to 150 mm.

*** SET OK ***

02: ZONE=0~100mm

- Recording zone settings are complete.

6.3.2 Error Code Summary Table

	Error Number	Error Description
Settings	001	Main recorder-related errors other than those below
	002	Value entered exceeds allowable setting range.
	003	Time setting error
	004	Attempted to enter a channel which cannot be selected.
Recording	010	Command error in GP-IB communication
	011	Attempted to record setting list when out of chart.
	020	Attempted to repeat setting list recording while setting list recording already in progress.
Range	040	Current DELTA channel larger than reference channel
	041	DELTA target channel set up for SKIP
	042	DELTA target channel set up for DI
	043	DELTA target channel set up for SCALE
	045	Left SPAN value same as right value
	046	Left SCALE value same as right value
Alarm	060	Attempted to set alarm on channel with range setting for SKIP.
	061	Attempted to set alarm on channel setting for DI.
	062	Non-existent relay number entered.
AUX	082	SET-UP RECORD PARTIAL setting is OFF (partial compression).
	083	Channel set to PARTIAL has range set to SKIP (partial compression).
	084	Channel set to PARTIAL has range set to DI (partial compression).
	086	Left zone value is same as right value.

	Error Number	Error Description
AUX	087	Left zone value is larger than right value.
	088	Band between left and right zone values is less than 5 mm.
	090	Computation options 31 through 60 non-existent.
	091	Syntax error in CONST (constant) entry.
	092	Setting exceeds allowable CONST (constant) range.
	094	Attempted to set more than 11 channels to interpolation ON.
	096	Attempted to set system ON alarm mode to other than NONE when set up CONTL boundary is EXT.
IC Memory Card	120	Card error <ul style="list-style-type: none"> • IC card not plugged in. • Not properly formatted.
	121	Card capacity error <ul style="list-style-type: none"> • Insufficient capacity to create file.
	122	File name error <ul style="list-style-type: none"> • File name is all spaces. • File name includes space(s). • File name includes *, ?, +, /, :, or comma. • File name begins with AUX, COM, PRN, NUL, or CLOCK.
	123	Sampling/playback execution error <ul style="list-style-type: none"> • Sampling designation entered while sampling in progress. • Designation entry repeated during data playback.
	124	Directory error <ul style="list-style-type: none"> • Directory full – cannot register new file.
	125	Creating device type error <ul style="list-style-type: none"> • Attempted playback of file created on non-HR device. (Data file, setting file).
	126	Write-protect violation error (Hybrid recorder itself) <ul style="list-style-type: none"> • HR setting for write prohibition by SET UP mode

		Error Number	Error Description
IC Memory Card		127	Write-protect violation error (IC Memory Card) • The file is write-protected.
		128	Trigger source error • All trigger sources were disabled during trigger mode SET UP.
		129	Playback start-point error • Playback start-point exceeded actual number of data samples.
		130	Channel number error • No target channels for data sampling. • Too many data playback channels.
		131	Data count error • Number of data points is 0 or greater than 32,000.
		132	File format error • Wrong file format
		133	No file name
		134	Setting file error
		139	Other IC card related error
		140	Undefined code error
Computa- tion		141	Number of parentheses doesn't match
		142	Specified function for which multiple instances are not allowed.
		143	Context error Example: 01*+02
		144	Invalid computation expression channel number or GROUP input error Example : 31=32+33 31=G1+34 (if G1=31 or 33)
		145	Statistical function input error
Communi- cations		160	Communications-related error

Description of Basic Function, Operation, Setting

6.4 Panel Operation Description

6.4.1 Names and Functions of Individual Keys

(1) [Recording-Related Keys]

HR1300




Figure 6.4.1 HR1300 Recording-Related Key Names

CAUTION

Do not press the keys with a screwdriver, a mechanical pencil, the end of a nail or any other sharp object. Otherwise, they may be damaged.

① Recording START/STOP Key

Each press of this key alternately starts (LED lit) or stops (LED OFF) recording.

- The initial setting conditions for recording are as follows:

Recording format : TREND

Recording interval mode : AUTO

Chart speed : 100 mm/h

- See the following manual sections for setting change procedures:

To change recording format

AUX

 SYSTEM (Section 6.10.2)

To change recording interval

AUX

 SYSTEM (Section 6.10.2)

To change chart speed

CHART

 (Section 6.9)

To change recorder operating mode

AUX

 SYSTEM (Section 6.10.2)

Print-on alarm

Change-on alarm

To change recording color SET-UP mode COLOR (Section 6.11.9)

To change scanning interval SET-UP mode INTVL (Section 6.11.2)

② HEADER Key

Lights LED and prints header information onto chart.

(Not set at time of shipment. See Section 6.10.6.)

③ LIST Key

Lights LED and prints out setting list for RANGE and ALARM, etc.

(※ If you wish to start a SET-UP mode list printout,
press the

FUNC

 key, and select "SL-ON".)

6.4

④ MAN PRINT Key

Gives a logging record of a single scan of data.

(LED lights and analog recording stops.)

When the writing of the single scan of data is complete, the LED turns OFF, the MAN PRINT function is automatically cancelled, and the instrument returns to the recording previously in progress.

⑤ CHART FEED Key

Pressing this key causes the chart to feed as long as it is depressed.

⑥ KEY LOCK Key

Pressing this key lights the LED and locks all keys on the panel.

You can enable or disable key locking individually for PRINT, MAN-PRINT, LIST, CHART FEED and certain other keys. (See Section 6.11.4).

(2) [Display-Related Keys]




Figure 6.4.2 Display-Related Key Names

⑦ UPPER DISPLAY Changes

(Display Example)

01 d H 0.00 mV

02 d dH -123.00mV ▲AUTO

← Pressing the UPPER DISPLAY key displays the upper line of the display.

1. DATA AUTO Display (▲ AUTO)
Displays data for each channel in succession, for two seconds per channel.
2. DATA MAN Display (▲ MAN)
Displays data for one specified channel.
Channel is selected using the

CH UP △

 ,

CH DOWN ▽

 or

CH-SET

 keys.
3. ALARM SEARCH Display (▲ ALM)
Displays channels for which alarms are present, for two seconds per channel.

⑧ LOWER DISPLAY Change

(Display Example)

01 d H 0.00 mV

02 d dH -123.00mV ◀AUTO

← Pressing the LOWER DISPLAY key displays the lower line of the display.

1. DATA AUTO Display (\blacktriangleleft AUTO)
Displays data for each channel in succession, for two seconds per channel.
2. DATA MAN Display (\blacktriangleleft MAN)
Displays data for one specified channel.
Channel is selected using the

CH UP \triangle

 ,

CH DOWN ∇

 or

CH-SET

 keys.
3. ALARM SEARCH Display (\blacktriangleleft ALM)
Displays data for channels for which alarms are present, for two seconds per channel.

4. BAR GRAPH Display (◀BAR)


Displays a bar graph of the data for the channel being displayed on the upper line.

5. CLOCK Display (◀CLK)

Displays date and time of day.

- See Section 6.10.1 for time-changing procedure.

6. RELAY STATUS Display (◀RLY)




This mode allows you to monitor the output states of the internal alarm relays (I01 and I02).

- The figure above shows a display of the statuses of relays I01 and I02.
- The light boxes ☐ indicate output OFF, and the dark boxes ☒ output ON.
- To change the displayed group, use the and keys.

7. ALARM STATUS Display (◀OPT)


Note : In systems not having channels 31 through 60 this can be skipped.



This mode is used to monitor alarms occurring in optional channels 31 through 60.

- The above figure shows a display of the ALARM statuses of channels 31 through 40.
- The light boxes ☐ indicate no alarm, and the dark boxes ☒ that an alarm is present. If ALARM ACK ON has been selected in the SET-UP settings, the indicator will flash when an alarm is present. Pressing the ALARM ACK key stops the flashing and causes the indicator to show the current alarm status.
- In the case of display for channels 41 through 50 the display will read 41 instead of 31, and for channels 51 through 60 will read 51 instead of 31.
- To switch between the 31 group and the 41 or 51 group, use the and keys.

8. Other Displays



① : There is a "next" screen for call up by using the NEXT function key.

① : Information

② : CHANGE-ON ALARM

② : PRINT-ON ALARM

③ : Memory card in operation

③ : Memory card awaiting trigger

④ : Upper display

④ : Lower display

⑨ **Function Keys (F1 through F4)**

When selection items are displayed above the keys F1 through F4 during setting, they can be selected using those keys.

⑩ **NEXT Key (NEXT)**

When the mark is visible to the left of the function indicators on the display, this indicates that there are still more function key selections available. Press the NEXT key when you wish to see these selections. Continuing to press it will return you to the setting selections from which you started.

(3) [Alarm Display and Alarm Output Relay Related Keys]

When any of the alarms set on the individual channels occur (see Section 6.8, "Alarm Setting"), the corresponding LED for that channel 1 through 20 on the front panel will begin flashing (ALM ACK must be set to ON in the SET-UP mode CONTROL selections).

When the MATH option is installed, the "31 through 60" indicator will also flash if alarms occur.




Figure 6.4.3 Alarm Display and Alarm Output Relay Related Key Names

⑪ ALARM ACK Key

This key stops the flashing of the alarm status indicator for the channel in alarm, and causes it to show the current alarm status (lit if in alarm, OFF if recovered from alarm). If a new alarm occurs in some channel after this key is pressed, that channel's alarm status indicator will begin to flash.

NOTE

1. This mode of operation is in effect only if ALM ACK = ON was selected in SET-UP mode.
2. The common output relay, too, will turn OFF (internal alarm output relay [when installed as option]).

⑫ ALARM RESET Key

When alarms have occurred and relays are generating outputs from the internal alarm output relay unit (optional), pressing this key will reset all the relay outputs to the OFF condition. This capability is enabled when RELAY HOLD or ALM ACK = ON has been selected in the setting CONTROL mode.

(Display Description)

The display shows the status of the alarms (see Section 6.8, "Alarm Setup") set for each of the individual channels 1 through 20. For computation channels (channels 31 through 60) the 31 to 60 indicator displays the status.

If ALM ACK has been set to ON in SET-UP:

The alarm indicator begins flashing when an alarm occurs. (The alarm flashing will be maintained even if the channel recovers from alarm.)

If ALM ACK has been set to OFF in SET-UP:

The alarm indicator turns ON when the alarm occurs and turns OFF when the channel recovers from alarm.

(4) [Entry Setting Related Keys]




Figure 6.4.4 Setting Entry Related Key Names

⑬ ENTRY Key (**ENTRY**)

Pressing this key after completing a setting puts the displayed setting(s) into effect.

⑭ Numerical Keys (Including **SHIFT** and **CAPS** Keys)

These keys are used to input numerals and letters during setting. The character input is displayed at the cursor position.










(1) **CAPS** Key

Pressing this key once turns ON the LED, pressing it again turns the LED OFF. Capital letters are entered in upper case when the LED is ON, and small letters are entered in lower case when the LED is OFF.


(2) **SHIFT** Key


Pressing this key once turns ON the upper left LED, pressing it a second time turns ON the upper right LED, and pressing it a third time turns the LEDs OFF. These three modes enable input as follows:

- When both LEDs are OFF, numerals Example: **G 7 W** key inputs "7"
- When left LED is ON, letters at upper left Example: **G 7 W** key inputs "G"
- When right LED is ON, letters at lower right Example: **G 7 W** key inputs "W"

- ⑮  ,  ,  ,  Keys (Cursor Movement, Screen Forward / Back Shift)
-   : These keys move the cursor indicating the input position left and right.
(Example) -0002 V
 Cursor
 -   : These keys are used to return the input screen back by one or to advance it forward.

- ⑯ Channel Change Keys (, , Keys)

 : Key used to change the selected channel number (in the direction of higher numbers)

 : Key used to change the selected channel number (in the direction of lower numbers)

The sequencing of channels is as follows:

Standard : CH1 to CH20, G1 (Group 1) to G6 (Group 6)
(Groups not selectable will cause an error.)

With MATH option : CH1 to CH20, CH31 to CH60, G1 to G6

See Section 6.11.6, "Group Setting", concerning group (G1 through G6) selection, and the separate user manual for the MATH option concerning CH31 through CH60.

CH-SET : This key is used to change the selected channel to one specified by numerical entry.

CHANNEL NO.=01

↓▶ Ch=01~20 G1=01~10 G2=11~20

↓▶ Ch=01~20 G3=01~15 G4=01~20

...

- Entering 01 through 20 selects the specified channel.
- Entering G1 through G6 selects the individual group.

- ⑰ RANGE Setting Key (RANGE Key)

Used to set the measurement range. (See Section 6.7, “Range Setting”).

- ⑱ ALARM Setting Key (ALARM Key)

Used to set alarms. (See Section 6.8, “Alarm Setting”.)

- ⑱ AUX Function Setting Key (AUX Key)

Used to change settings of parameters peculiar to hybrid recorders. (See Section 6.10, "Settings Under AUX").

(CLOCK, Format (TREND / LOGGING),
Operating Mode (Print-On-Alarm, Change-On-Alarm),
Recording Interval Mode (AUTO / FIX))

⑳ **CHART SPEED Setting Key (CHART Key)**

Used to set chart speed.

㉑ **LOCAL Key (LOCAL Key)**

Used to set communications to LOCAL mode during GP-IB communications.

(Linked to REMOTE indicator. Turns off REMOTE indicator.)

㉒ **MEMORY Key**

Used for setting when IC memory cards are in use. (See Section 7. "IC Memory Card".)

㉓ **FUNC Key**

This key calls up the following screen:

FUNC=SETUP-LIST ON			
<div style="border: 1px solid black; display: inline-block; padding: 2px;"> ▼SL-ON </div>	SL-OFF	MSG-P	ESC
INIT	A-INIT	M-INIT	I-RST

- ① SL-ON : Initiates a list printout of the SET UP information.
- ② SL-OFF : Stops the SET-UP LIST printout.
- ③ MSG-P : Initiates printout of messages.
(MESSAGE PANEL setting information in AUX mode.)
- ④ INIT : Initializes the internal settings.
- ⑤ A-INIT : Clears alarm printout memory.
- ⑥ M-INIT : Clears message printout memory.
- ⑦ I-RST : Intervals are reset in multiple mode.
(Invalid in single mode)
- ⑧ ESC : Return to display mode.

6.4.2 Other Displays




Figure 6.4.5 Miscellaneous Indicator Names

24 TREND, LOG, REMOTE, CHART, MAIN BAT and CARD BAT


- | | | |
|---|---|--|
| TREND | : | Lights up when digital + analog trend recording is in progress. |
| LOG | : | Lights up when digital-only recording is in progress. |
| REMOTE | : | Lights up when recorder is in REMOTE status (communication-enabled status) with GP-IB communications. |
| CHART | : | Lights up when incipient chart end is detected. When this indicator lights up, recording is halted after more 10mm of chart advance, and the recorder goes into a measurement-display-only mode. |
| <p>(Note : If an IC Memory Card is used, it is possible to set it so that data acquisition to the card begins simultaneously with chart end.)</p> | | |
| MAIN BAT | : | Lights up when setting status backup battery voltage drops. For a standard model, battery life is about 10 years. A service person should be called to replace the battery. |
| CARD BAT | : | Lights up when the IC Memory Card internal backup battery voltage drops. See Section 7.1.3 for the battery installation and replacement procedure. |

25 FAIL



Lights up when a malfunction occurs inside the recorder. If this indicator lights up, turn power OFF and contact your agent or service shop.

6.5 Setting Flowchart


6.5.1 Setting Flow (Page number)



6.5





AUX



6.5

SET UP







6.5.2 Setting Information Summary (RANGE, ALARM and AUX Keys) 1/2

Setting Parameter		Function Keys					Menu Content	Remarks
		F1	F2	F3	F4	NEXT		
RANGE (CHANNEL, GROUP)	MODE	SKIP	VOLT	TC	RTD	○	Normal measurements, skip, difference calculation	DELTA : difference calculation SCALE: used for scaling values
		DI	DELTA	SCALE				
	VOLT (MODE)	20mV	60mV	200mV	2V	○	DC voltage input	
		6V	20V	50V				
	TC (MODE)	R	S	B	K	○	Thermocouple input	
		E	J	T	N	○		
		W	L(J)	U(U)	KpAuFe			
	RTD (MODE)	PT1	PT2	PT3	PT4	○	RTD input Pt1: Pt100, 1mA JPt. Cu1: Cu10, GE Pt2: Pt100, 2mA JPt. Cu2: Cu10, L&N Pt3: Pt50, 2mA JPt. Cu3: Cu10, WEED Pt4: Pt100, 1mA Cu4: Cu10, BAILEY Pt5: Pt100, 2mA Pt6: Pt100, 1mA, High sensitivity (JPt) Pt7: Pt100, 2mA, High sensitivity (JPt) Pt8: Pt100, 1mA, High sensitivity Pt9: Pt100, 2mA, High sensitivity Ni1: Ni100, 1mA SAMA Ni2: Ni100, 1mA DIN Ni3: Ni120, 1mA	
		PT5	NI1	NI2	NI3	○		
		CU1	CU2	CU3	CU4	○		
		PT6	PT7	PT8	PT9	○		
		J263						
	DI (MODE)	DI1	DI2				DI1: voltage input DI2: contact input	
	DELTA						Set differential computation	
	MODE (SCALE)	VOLT	TC	RTD				
ALARM (CHANNEL, GROUP)	LEVEL	1	2	3	4	○	Number of alarms per channel	
		5	6					
	ALARM	ON	OFF				Alarm ON/OFF	The following designation is made only at alarm ON.
	TYPE	H	L	RH	RL		Alarm type	
		(dH)	(dL)					
	VAL						Alarm value	
	RELAY	ON	OFF				Relay output ON/OFF	The following relay No. designation is made only at relay output ON.
	RELAY No.						Relay No.	
AUX	AUX MODE	CLOCK	SYSTEM	PRINT	TAG	○		
		MSG	HEADER	ZONE	PART	○		
		INTVL	CHART	INTPL	MOVAVE	○		
		31 to 60	CONST					
	SYSTEM	FORMAT	TREND	LOG			Determines recording format.	
		ON ALARM	NONE	PRINT	CHANGE		Print-on-alarm Change-on-alarm	
		TREND	FIX	AUTO			Switch to trend recording mode	
	PRINT	TREND PRINT	ON	OFF			Trend recording ON/OFF	
		DIGITAL PRINT	ON	OFF			Digital recording ON/OFF	
		INTVL No.	1	2	3		Interval No. when in multiple mode	
	TAG	TAG					Tag input	
	MESSAGE		TITLE	PANEL	CONT-1	CONT-2	○	Message input
			CONT-3	CONT-4	CONT-5	ALM-1	○	
			ALM-2	ALM-3	ALM-4	ALM-5		


Setting Information Summary (RANGE, ALARM and AUX Keys) 2/2

Setting Parameter			Function Keys					Menu Content	Remarks
			F1	F2	F3	F4	NEXT		
AUX	HEADER	HEADER LINE	1	2	3	4	○	Specify header lines	
			5						
		LINE						Header input	
	ZONE							Zone recording width entry L:0 to 145, R:5 to 150	
	PART	PARTIAL	ON	OFF				Partial compression recording selection	
		RATE						Compression rate entry	
		BDY						Boundary point entry	
	INTVL	INTVL1 to 3						Logging interval setup	INTVL2, 3 are set only when logging mode is MULTIPLE.
		START TIME	ON	OFF				Start time setup	
	CHART'	CHART SP'						Chart speed for change-on-alarm	
		INTVL'						Logging interval for change-on-alarm	
	INTRPL		ON	OFF				Analog recording interpolation function ON/OFF selection	
	MOVEAVE	MOVE AVERAGE	ON	OFF				Moving average function ON/OFF selection	
	31 TO 60							Computation channel (31 through 60) selection	
								(Memory, digital input,) analog recording	
	CONST							Entry of constants used in computations	


6.6 Channel Number Specification (Group Specification)


When making range or alarm settings during measurement, channel numbers can be specified using the **CH UP**  and **CH DOWN**  keys. Invalid channel No. and groups are ignored.

Range Setting Screen



The screen shows a top line with "01:MODE=VOLT" and a bottom line with a selection menu: "SKIP VOLT TC RTD". An arrow points from the text "Channel No." to the "01" in the top line.

Alternatively, if you wish to move from channel 1 to channel 20, pressing the **CH-SET**  key and entering "20" on the screen below,




The screen shows a top line with "CHANNEL NO.=01" and a bottom line with "▶↓Ch=01~20 G1=01~10 G2=11~20". An arrow points from the text "Displays applicable channels and set data in all groups." to the bottom line.

will call up the range setting screen for channel 20.

6.6

<Group Specification>

If you wish to use Group 1 to make entries for channels 1 through 10 together, input "G1".



The flowchart shows two screens. The top screen has "CHANNEL NO.=G1" and "▶↓Ch=01~20 G1=01~10 G2=11~20". A downward arrow points to the bottom screen, which has "G1:MODE=VOLT" and "SKIP VOLT TC RTD".

※ To change the channels making up G1, use SET UP to change the channel numbers included in the group.

The following are limited to make group settings:


- Channels 01 to 20, and 31 to 60 must be set individually as a group.
- In RANGE and MOV-AVE modes, groups including channels 31 through 60 are invalid.
- For setting channels 31 to 60, groups that include channels 01 to 20 are invalid.
- For alarm settings, different modes and ranges in a group are invalid.
- For partial range settings, different modes, ranges and span in a group are invalid.
- Interpolations cannot be set into a group.

6.7 Range Setting

Range setting selects the measurement input type and sets the recording range.

- SKIP : Deletes the specified channel from the set of those measured.
- VOLT : Measures voltage (DC).
- TC : Measures temperature using thermocouple (TC).
- RTD : Measures temperature using resistance temperature detector (RTD).
- DI : Accepts contact input (to record operation).
- DELTA : Performs difference computation.
- SCALE : Performs scaling on DC, TC or RTD measurement and append units.

- Pressing the **RANGE** key displays the first setting screen.



The selections are explained sequentially below.

- Set the range information for all channels.
- You can also set multiple channels at one time by using the group function. (See Section 6.11.6.)
- When the recording span, scaling value, and engineering units are being set, use numerical and alphabetical keys.

Example 1. To set the "left" span at 125.00 as a scaling value:

Press the keys: **M 1 .** **N 2 #** **K 5 (** **F . v** **P 0 :** **P 0 :**

Example 2. To set the engineering units in kg/m²:

Press the keys: **SHIFT** **K 5 (** **SHIFT** **G 7 w** **E I u** **SHIFT**
M 1 . **N 2 #**

- * To change from upper-case alphabetical characters to lower-case characters—and vice versa—press the **CAPS** key.

{ **CAPS** lamp lights up upper-case characters
CAPS lamp turns off lower-case characters

Input Range Tables

1. DC Voltage Input

Input Category	Selected Range	Input Type	Measurement Range	Recording Units	Remarks
DC Voltage	20 mV	20 mV	- 20.000 to 20.000 mV	mV	
	60 mV	60 mV	- 60.00 to 60.00 mV	mV	
	200mV	200mV	- 200.00 to 200.00 mV	mV	
	2 V	2 V	- 2.0000 to 2.0000 V	V	
	6 V	6 V	- 6.000 to 6.000 V	V	
	20 V	20 V	- 20.000 to 20.000 V	V	
	50 V	50 V	- 50.00 to 50.00 V	V	

6.7

2. Thermocouple / RTD / Contact Inputs

Input Category	Selected Range	Input Type	Measurement Range		Remarks
			°C	°F	
Thermocouple	R	Type R	0.0 to 1760.0 °C	32 to 3200 °F	
	S	Type S	0.0 to 1760.0 °C	32 to 3200 °F	
	B	Type B	0.0 to 1820.0 °C	32 to 3308 °F	
	K	Type K	-200.0 to 1370.0 °C	-328 to 2498 °F	Old CA
	E	Type E	-200.0 to 800.0 °C	-328.0 to 1472.0 °F	Old CRC
	J	Type J	-200.0 to 1100.0 °C	-328.0 to 2012.0 °F	Old IC
	T	Type T	-200.0 to 400.0 °C	-328.0 to 752.0 °F	Old CC
	N	Type N	0.0 to 1300.0 °C	32 to 2372 °F	NBS
	W	Type W	0.0 to 2315.0 °C	32 to 4199 °F	OMEGA
	L	Type L (Fe-CuNi)	-200.0 to 900.0 °C	-328.0 to 1652.0 °F	DIN 43710
	U	Type U (Cu-CuNi)	-200.0 to 400.0 °C	-328.0 to 752.0 °F	DIN 43710
RTD	KpAuFe	Kp VS Au7Fe	0.0 to 300.0 K	0.0 to 300.0 K	
	PT 1	JPt 100Ω	-200.0 to 550.0 °C	-328.0 to 1022.0 °F	Measurement current 1 mA
	PT 2	JPt 100Ω	-200.0 to 250.0 °C	-328.0 to 482.0 °F	2 mA
	PT 3	JPt 50Ω	-200.0 to 550.0 °C	-328.0 to 1022.0 °F	2 mA
	PT 4	Pt 100Ω	-200.0 to 600.0 °C	-328.0 to 1112.0 °F	1 mA
RTD (SAMA)	PT 5	Pt 100Ω	-200.0 to 250.0 °C	-328.0 to 482.0 °F	2 mA
	NI 1	Ni 100Ω	-200.0 to 250.0 °C	-328.0 to 482.0 °F	Measurement current 1 mA
RTD (DIN)	NI 2	Ni 100Ω	-60.0 to 180.0 °C	-76 to 356.0 °F	1 mA
RTD (McGraw Edison Company)	NI 3	Ni 120Ω	-70.0 to 200.0 °C	-94.0 to 392.0 °F	Measurement current 1 mA
RTD (High Sensitivity)	PT 6	JPt 100Ω	-140.00 to 150.00 °C	-220.0 to 302.0 °F	1 mA High sensitivity
	PT 7	JPt 100Ω	-70.00 to 70.00 °C	-94.0 to 158.0 °F	2 mA High sensitivity
	PT 8	Pt 100Ω	-140.00 to 150.00 °C	-220.0 to 302.0 °F	1 mA High sensitivity
	PT 9	Pt 100Ω	-70.00 to 70.00 °C	-94.0 to 158.0 °F	2 mA High sensitivity
RTD	J263	J263*B	0.0 to 300.0 K	0.0 to 300.0 K	
RTD* (Cu10, for sensors of particular makers)	CU 1	Cu 10Ω	-200.0 to 300.0 °C	-328.0 to 572.0 °F	For GE
	CU 2	Cu 10Ω	-200.0 to 300.0 °C	-328.0 to 572.0 °F	For L & N
	CU 3	Cu 10Ω	-200.0 to 300.0 °C	-328.0 to 572.0 °F	For WEED
	CU 4	Cu 10Ω	-200.0 to 300.0 °C	-328.0 to 572.0 °F	For BAILEY
Contact	DI 1	Voltage input	less than 2.4V=OFF, 2.6V or greater=ON		
	DI 2	Contact input	Contact ON/OFF		

* Ranges of guaranteed accuracy for Cu10 inputs :

CU 1 (Cu10, GE) : -84.4 to 170.0 °C, -119.9 to 338.0 °F

CU 2 (Cu10, L&N) : -75.0 to 150.0 °C, -103.0 to 302.0 °F

CU 3 (Cu10, WEED) : -200.0 to 250.0 °C, -328.0 to 482.0 °F

CU 4 (Cu10, BAILEY) : -200.0 to 250.0 °C, -328.0 to 482.0 °F

R, S, B, K, E, J, T:
ANSI, IEC 584, DIN IEC 584
JIS C 1602-1981
L: Fe-CuNi, DIN 43710
U: Cu-CuNi, DIN 43710
N: Nicrosil-Nisil
IEC 584, DIN IEC 584
W: W-5%Re-W-26%Re
Hoskins Mfg Co.

KP vs Au7Fe: NBS Vol.76A
Pt100: JIS C 1604-1989, JIS C 1606-1989
IEC 751, DIN IEC 751
Jpt100: JIS C 1604-1989, JIS C 1606-1989
Pt50: JIS C 1604-1981, JIS C 1606-1984
Ni100: SAMA, DIN 43760
Ni120: McGraw E-DISON
J263 * B (PT-Co 0.5 no 1%): YOKOGAWA

6.7.1 Voltage (VOLT) Measurement Setting

The following describes range setting when the measured signal is a DC voltage.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **RANGE** , *** F2** , **ENTRY**

01:MODE=VOLT

↓SKIP VOLT TC RTD ← LOWER DISPLAY

↓DI DELTA SCALE

Key entry : *** F4** , **ENTRY**

01:RANGE=2V

↓20mV 60mV 200mV 2V

↓6V 20V 50V

Key entry : *** [Alphanumeric keys]** , **ENTRY**

01:SPAN L=-2.0000V

▶ 2V RNG -2.0000~2.0000V ← Allowable entry range


Key entry : *** [Alphanumeric keys]** , **ENTRY**

01:SPAN R=2.0000V

▶ 2V RNG -2.0000~2.0000V

*** SET OK ***

01:2V -2.0000~2.0000V

- Setting DC voltage (DC VOLT) input.
- Select from the LOWER DISPLAY using the function key.
- Press **ENTRY** to accept the selection and advance to the next screen.
- Choose from among the voltage input range selections.
- Input the recording span left value.
- Input the value via the numeric key by referring to the allowable input range on the LOWER DISPLAY.
- The decimal point is automatically set depending on the range code.
- Input the recording span right value.
- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the **UPPER DISPLAY** key.

6.7.2 Thermocouple (TC) Measurement Setting

The following describes range setting when the measurement sensor is a thermocouple.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **RANGE** , * **F3** , **ENTRY**

01:MODE=TC

↓SKIP VOLT TC RTD ← LOWER DISPLAY

↓DI DELTA SCALE

Key entry : * **F4** , **ENTRY**

01:RANGE=TYPE-K

↓R S B K

↓E J T N

↓W L U KpAuFe

Key entry : * **Alphanumeric keys** , **ENTRY**

01:SPAN L=-200.0°C

▶ K RNG -200.0~1370.0°C ← Allowable input range


Key entry : * **Alphanumeric keys** , **ENTRY**

01:SPAN R= 200.0°C

▶ K RNG -200.0~1370.0°C

*** SET OK ***

01:TYPE-K -200.0~200.0°C

- Set a thermocouple (TC) input.
- Select from the LOWER DISPLAY using the function key.
- Press **ENTRY** to accept the selection and advance to the next screen.
- Select the thermocouple type.
- Input the recording span left value.
- Input the value via the numeric key by referring to the allowable input range on the LOWER DISPLAY
- The decimal point is automatically set depending on the range code.
- Input the recording span right value.
- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the UPPER DISPLAY key.

6.7.3 Resistance Temperature Detector (RTD) Measurement Setting

The following describes range setting when the measurement sensor is a resistance temperature detector (RTD).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **RANGE** , * **F4** , **ENTRY**

01:MODE=RTD

↓SKIP	VOLT	TC	RTD
↓DI	DELTA	SCALE	

← LOWER DISPLAY

Key entry : * **F4** , **ENTRY**

01:TYPE=Pt100:1

↓PT1	PT2	PT3	PT4
↓PT5	NI1	NI2	NI3
↓CU1	CU2	CU3	CU4
↓PT6	PT7	PT8	PT9
↓J263			

Key entry : * **Alphanumeric keys** , **ENTRY**

01:SPAN L=-200.0°C

▶ PT4 RNG -200.0~600.0°C


Key entry : * **Alphanumeric keys** , **ENTRY**

01:SPAN R= 500.0°C

▶ PT4 RNG -200.0~600.0°C

*** SET OK ***

01:Pt100:1 -200.0~500.0°C

- Set a resistance temperature detector (RTD) input.
- Select from the LOWER DISPLAY using the function key.
- Press **ENTRY** to accept the selection and advance to the next screen.
- Select the RTD input type.
- Input the recording span left value.
- Input the value via the numeric key by referring to the allowable input range on the LOWER DISPLAY.
- The decimal point is automatically set depending on the range code.
- Input the recording span right value.
- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the UPPER DISPLAY key.

(RTD Type Description)

LOWER DISPLAY	UPPER DISPLAY
PT1	JPt100 : 1
PT2	JPt100 : 2
PT3	Pt50 : 2
PT4	Pt100 : 1
PT5	Pt100 : 2
NI1	Ni100 : 1-SAMA
NI2	Ni100 : 1-DIN
NI3	Ni120 : 1
CU1	Cu10 : GE
CU2	Cu10 : L&N
CU3	Cu10 : WEED
CU4	Cu10 : BAILEY
PT6	JPt100 : 1-H
PT7	JPt100 : 2-H
PT8	Pt100 : 1-H
PT9	Pt100 : 2-H
J263	J263*B

High-
sensitivity

6.7.4 Setting for Recording Operations Using Contact Input (DI)

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **RANGE** , **NEXT** , * **F1** , **ENTRY**

01:MODE=DI

↓SKIP VOLT TC RTD ← LOWER DISPLAY

↓DI DELTA SCALE

- Set to record equipment operations using contact inputs (DI).
- Select from the LOWER DISPLAY using the function key.

Key entry : * **F1** , **ENTRY**

01:RANGE=VOLT

DI1 DI2


- Determine the contact input type.

DI1 : (VOLT) Records ON/OFF status of a voltage input.
(0 to 2.4V is OFF, 2.4V and higher is ON)

DI2 : (CONTACT) Records ON/OFF status of a mechanical contact.


*** SET OK ***

01:DI VOLT

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the UPPER DISPLAY key.

The selections made up to this point will result in a recording trace traversing from 0 to 150 mm between the contact OFF and ON states. You should follow the instructions in Section 6.10.7 "Zone Recording Setting" to set a zone for the ON/OFF record.

Example : OFF ON



6.7.5 Difference Computation Setting

The following describes the range setting used to obtain the difference between the measured values of two channels.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **RANGE** , **NEXT** , * **F2** , **ENTRY**

10:MODE=DELTA

↓SKIP VOLT TC RTD ← LOWER DISPLAY

↓DI DELTA SCALE

Key entry : **P 0** , * **M 1** , **ENTRY**

10:REF CH=01

▶ INPUT REF CHANNEL (01~09)

Key entry : * **Alphanumeric keys** , **ENTRY**

10:SPAN L=-1.0000V

▶ 2V DLT -2.0000~2.0000V

Key entry : * **Alphanumeric keys** , **ENTRY**

10:SPAN R= 1.0000V

▶ 2V DLT -2.0000~2.0000V

*** SET OK ***


10:DELTA 01 -1.0000~1.0000V

- Set a difference computation (DELTA) input.
- Select from the LOWER DISPLAY using the function key.

- Input the reference channel for the difference computation.
Note : The channel number of the reference channel must be lower than that of the channel being setting.

- Input the recording span left value.
- The range will be automatically set to the same range as the reference channel.
- Input the value via the numeric key by referring to the allowable input range on the LOWER DISPLAY.

- Input the recording span right value.

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the UPPER DISPLAY key.

<Allowable Range Settings and Maximum Span Values for Difference Computation Mode>

(1) Thermocouple (TC)

	°C	°F		°C	°F
	Range	Range		Range	Range
R	-1760.0 to 1760.0	-3168 to 3168	T	-600.0 to 600.0	-1080.0 to 1080.0
S	-1760.0 to 1760.0	-3168 to 3168	N	-1300.0 to 1300.0	-2340 to 2340
B	-1820.0 to 1820.0	-3276 to 3276	W	-2315.0 to 2315.0	-4167 to 4167
K	-1570.0 to 1570.0	-2826 to 2826	L	-1100.0 to 1100.0	-1980.0 to 1980.0
E	-1000.0 to 1000.0	-1800.0 to 1800.0	U	-600.0 to 600.0	-1080.0 to 1080.0
J	-1300.0 to 1300.0	-2340.0 to 2340.0	Kp vs Au7Fe	-300.0K to 300.0K	-300.0K to 300.0K

(2) Resistance Temperature Detector (RTD)

	°C	°F		°C	°F
	Range	Range		Range	Range
Pt100:1 JPt100:1	-750.0 to 750.0	-1350.0 to 1350.0	Cu10:GE	-500.0 to 500.0	-900.0 to 900.0
Pt100:2 JPt100:2	-450.0 to 450.0	-810.0 to 810.0	Cu10:L & N	-500.0 to 500.0	-900.0 to 900.0
Pt50:2	-750.0 to 750.0	-1350.0 to 1350.0	Cu10:WEED	-500.0 to 500.0	-900.0 to 900.0
Pt100:1	-800.0 to 800.0	-1440.0 to 1440.0	Cu10:BAILEY	-500.0 to 500.0	-900.0 to 900.0
Pt100:2	-450.0 to 450.0	-810.0 to 810.0	Pt100:1 (JPt) High sensitivity	-290.00 to 290.00	-522.0 to 522.0
Ni 100:1 DIN	-240.0 to 240.0	-432.0 to 432.0	Pt100:2 (JPt) High sensitivity	-140.00 to 140.00	-252.0 to 252.0
Ni 100:1 SAMA	-450.0 to 450.0	-810.0 to 810.0	Pt100:1 High sensitivity	-290.00 to 290.00	-522.0 to 522.0
Ni 120:1	-270.0 to 270.0	-486.0 to 486.0	Pt100:2 High sensitivity	-140.00 to 140.00	-252.0 to 252.0
J263+B	-300.0K to 300.0K	-300.0K to 300.0K			

(3) DC Voltage

Range	Range
20 mV	-20.000 to 20.000
60 mV	-60.00 to 60.00
200 mV	-200.00 to 200.00
2 V	-2.0000 to 2.0000
6 V	-6.000 to 6.000
20 V	-20.000 to 20.000
50 V	-50.00 to 50.00

6.7.6 Scaling Setting (with Unit Assignment Capability)

The following describes the range setting used for scaling measured data.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **RANGE** , **NEXT** , * **F3** , **ENTRY**

01:MODE=SCALE

↓SKIP VOLT TC RTD ← LOWER DISPLAY

↓DI DELTA SCALE

- Setting for scaling.
- Select from the LOWER DISPLAY using the function key.

Key entry : * **F1** , **ENTRY**

01:MODE'=VOLT

VOLT TC RTD

- Specify whether the input type to be scaled is voltage (VOLT), thermocouple (TC), or resistance temperature detector (RTD).

This example shows scaling for a voltage input.

Key entry : * **F4** , **ENTRY**

01:RANGE=2V

↓20mV 60mV 200mV 2V

↓6V 20V 50V

- Use a 2V voltage range.

Key entry : * **Alphanumeric keys** , **ENTRY**

01:SPAN L=-2.0000V

▶ 2V RNG -2.0000~2.0000V ← Allowable entry range

- Input the recording span left value.
- Input the value via the numeric key in referring to the allowable input range on the LOWER DISPLAY.
- The decimal point is automatically set depending on the range code.

Key entry : * **Alphanumeric keys** , **ENTRY**

01:SPAN R= 2.0000V

▶ 2V RNG -2.0000~2.0000V

- Input the recording span right value.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : * **Alphanumeric keys** , **ENTRY**

01:SCALE L= 0.0

▶ scale span -2.0000~2.0000

- Input the scale value corresponding to the span left value entered two screens before. Include the decimal point position in the input. (In this example, -2.0000V will be scaled to "0.0". The allowable input range is -20000 to +20000.)

Key entry : * **Alphanumeric keys** , **ENTRY**

01:SCALE R= 100.0

▶ scale span -2.0000~2.0000

- Input the scale value corresponding to the span right value entered two screens before. (In this example, +2.0000V will be scaled to "100.0".)
- The decimal point for span right is automatically set to the same position as that for span left.

Key entry : **SHIFT** , **CAPS** , **K 5** , **CAPS**
SHIFT , **G 7 W** , **ENTRY**


01:UNIT= Kg

▶ Up to 6 Characters

- Append units to the scaled value. Up to six characters can be input.

*** SET OK ***

01:SCALE 0.0~100.0Kg

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the UPPER DISPLAY key.

6.7.7 Skip Setting

The recorder can be setting so as not to perform data measurement, recording and display for unused channels.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : RANGE , * F1 , ENTRY

01:MODE=SKIP

↓SKIP VOLT TC RTD

- Set to skip No.1 channel.

*** SET OK ***

01:SKIP

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing ENTRY again will return you to the starting screen.
- To proceed to the next channel, press CH UP Δ to change the channel number.
- To return to the data display mode, press the UPPER DISPLAY key.

CAUTIONS

1. Alarms are automatically turned OFF on the affected channel when the following types of changes are performed. Exercise care when making these changes.
 - (1) When measurement mode (SKIP, VOLT, TC) is changed.
 - (2) When measurement range is changed.
 - (3) When any of the following are changed, if scaling is ON.
 - Decimal point position for linear scaling
 - Measurement mode (VOLT, TC, RTD) or range
 - Scaling LEFT
 - Scaling RIGHT
 - Span LEFT
 - Span RIGHT
 - (4) Difference alarms (dH, dL) only are turned OFF in the case of DELTA (channel-to-channel difference) when the reference channel is changed or the reference channel measurement mode or range is changed.

2. Partial compression/expansion is automatically turned OFF on the affected channel when the following types of changes are performed. Exercise care when making these changes.
 - (1) When measurement mode (SKIP, VOLT, TC) is changed.
 - (2) In the case of DELTA (channel-to-channel difference), when the reference channel is changed
 - (3) When measurement range is changed.
 - (4) When any of the following are changed, if scaling is on.
 - Decimal point position for linear scaling.
 - Measurement mode (VOLT, TC, RTD) or range
 - Scaling LEFT
 - Scaling RIGHT
 - Span LEFT
 - Span RIGHT
 - (5) When the recording span is changed.

3. When, in the case of DELTA (difference computation), the reference channel measurement mode (SKIP, VOLT, TC) or the measurement range is changed, the channel which was performing the difference computation will be released from difference computation mode and its span values will be set to the range maximum (right) and minimum (left).

Examples :

{		<u>Measurement Mode</u>	<u>Range</u>	<u>SPAN L</u>	<u>SPAN R</u>
	01ch	TC	Type-T	-100.0	300.0
			<u>Reference Channel</u>	<u>SPAN L</u>	<u>SPAN R</u>
	02ch	DELTA	01ch	-100.0	100.0

Assume that the setup is as above, and that channel 01 is changed as follows.

	<u>Measurement Mode</u>	<u>Range</u>	<u>SPAN L</u>	<u>SPAN R</u>
※ 01ch	VOLT	2V	-2.0000	2.0000

This cancels difference computation on channel 02, which becomes as follows.

	<u>Measurement Mode</u>	<u>Range</u>	<u>SPAN L</u>	<u>SPAN R</u>
※ 02ch	TC	Type-T	-200.0	400.0

6.8 Alarm Setting

- Alarms can be set on the measured data of any channel.
- The available alarm types are high and low limit (H, L), rate-of-change limits on increasing and decreasing signals (RH, RL), and high and low difference limits.
- Relay output numbers can also be assigned for alarm output relays (optional).
- Up to six alarms can be set per channel.
- Pressing the **ALARM** key displays the starting screen.
- Any alarm setpoint can be set with the numerical and alphabetical keys if it is within a settable range.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **ALARM** , * **F2** , **ENTRY**

01:LEVEL=2

↓1 2 3 4 ← LOWER DISPLAY

↓5 6

- Set the first alarm ON of channel No.1.
- Select the alarm level to be set from among those (1 to 6) listed in the LOWER DISPLAY.

Key entry : * **F1** , **ENTRY**

01/2:ALARM=ON

ON OFF ← Alarm level

- Turn ON the alarm for level 2 ON of channel No.1.

Key entry : * **F1** , **ENTRY**

01/2:TYPE=H

H L RH RL

dH dL ← Displayed only if channel 1 is set to the difference computation mode.

- Select a high limit (H) alarm for level 2 of channel No.1.

6.8

<Alarm Types>

H High Limit Alarm

Alarm is generated when the measured value is higher than the alarm setting.

L Low Limit Alarm



Alarm is generated when the measured value is lower than the alarm setting.

RH Rate-of-change Limit on Increase

Alarm is generated when the measured value variation in the ascending direction during the selected interval is greater than the alarm setting.

RL Rate-of-change Limit on Decrease

Alarm is generated when the measured value variation in the descending direction during the selected interval is greater than the alarm setting (treating both as signed values).

6.8

Note 1 : The selected interval is determined by the computation interval selected during rate-of-change alarm setup, Section 6.11.3 (8). (1 to 15 measurement scan intervals, initial value = 1 scan)

Note 2 : When any of the following conditions occurs, the measurement of variation for the ascending and descending rate-of-change alarms begins again from that instant.

- (1) Power is turned ON.
- (2) Measurement mode (VOLT, TC, RTD ...) is changed.
- (3) Measurement range is changed.
- (4) If scaling is ON, and any of the following are changed:
 - Span LEFT
 - Span RIGHT
 - Scaling LEFT
 - Scaling RIGHT
 - Decimal point position for linear scaling
- (5) Alarm turned ON or OFF in setup.
- (6) There are no more rate-of-change alarms.

dH Difference High-limit Alarm

Alarm is generated when the difference between the measured values of two channels is greater than the alarm setting.

dL Difference Low-limit Alarm

Alarm is generated when the difference between the measured values of two channels is less than the alarm setting (treating both as signed values).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : * **Alphanumeric keys** , **ENTRY**

01/2:VAL=100.0°C

▶ ALARM RNG — Differs depending on range.

- Input the alarm setting. An alarm will be generated when the measurement data reaches this value.

Key entry : * **F1** , **ENTRY**

01/2:RELAY=ON

ON OFF

- Select whether or not to provide a relay output using the alarm output relays (option).

Key entry : **SHIFT** , **9** , **P 0** : , **N 2** # , **ENTRY**

01/2:RELAY NO.=I02


▶ I**=INT E**=EXT S**=SWITCH

- Specify the number of the relay to use for output. Here we set internal output relay I02 as the output.

I01 through I02 Internal alarm output relays
S01 through S10 ... Internal (software) switches

*** SET OK ***

01/2 ON H 100.0°C I02

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting screen.
- To proceed to the next channel, press **CH UP**  to change the channel number.
- To return to the data display mode, press the **UPPER DISPLAY** key.

CAUTIONS

1. Alarm hysteresis can be set by the procedure in Section 6.11.3 (9).
2. Alarms cannot be set on DI or SKIP input measurements.
3. Alarms are automatically turned OFF on the affected channel when the following types of changes are performed. Exercise care when making these changes.
 - (1) When measurement mode (SKIP, VOLT, TC) is changed.
 - (2) When measurement range is changed.
 - (3) When any of the following are changed, if scaling is ON.
 - Measurement mode (VOLT, TC, RTD) or range
 - Span LEFT
 - Span RIGHT
 - Scaling LEFT
 - Scaling RIGHT
 - Decimal point position for linear scaling
 - (4) Difference alarms (dH, dL) only are turned OFF in the case of DELTA (channel-to-channel difference) when the reference channel is changed or the reference channel measurement mode or range is changed.
 - (5) Output relays can be used as OR or AND gates by assigning multiple alarms to a single relay.

Example :

<u>CH No.</u>	<u>Level No.</u>	<u>Mode</u>	<u>Alarm setting value</u>	<u>Relay No.</u>
02	5	H	100.0°C	I02
05	3	H	110.0°C	I02

I02 will turn on when an alarm is generated on either of channel 02 level 5 or channel 05 level 3 (when set for OR output).

The selection between OR and AND is done in setting mode as described in Section 6.11.3 (2), "Internal Alarm Relay Output AND/OR Selection".

6.9 Chart Speed Setting

- Chart speed setting selects the rate at which the chart is fed.
- Pressing the **CHART** key calls up the starting display.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **CHART** , **ASPO** , **M1** , **P0** , **P0**

CHART SP= 100mm/H

▶ Chart Speed: 1~1500mm/H ← LOWER DISPLAY

- Set the chart speed.

The allowable setting range is 1 to 1500 mm/hour.

Key entry : **ENTRY**

*** SET OK ***

CHART SPEED= 100mm/H

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the chart speed entered.
- Pressing **ENTRY** again will return you to the starting display.
- To return to the data display mode, press the **UPPER DISPLAY** key.

CAUTIONS

Selection of the chart speed that will go into effect when an alarm occurs for change-on-alarm, or when the remote control contact is ON, is performed using "CHART" in the **AUX** setting (Section 6.10.10).

There are two modes for analog recording interval : AUTO and FIX.

AUTO Analog recording interval is automatically determined based on chart speed.

FIX Interval is same as measurement interval.

AUTO/FIX selection is done using "SYSTEM" in **AUX** setting.

For details on this, see Section 6.10.2 (3), "Trend Recording Mode Selection".

6.9

- Relationship between chart speed and printing (when combining analog and digital recording)

(For recording of 30-point / 6-sec.)

Chart Speed	CH No. Tag No.	Date/Time Chart Speed Measured Value	Alarm Scale Value Messages (Titles)
1 to 9 mm/h	Recordable	Not recordable	Recordable
10 to 500mm/h	Recordable	Recordable	Recordable
501 to 1500mm/h	Not recordable	Not recordable	Not recordable

- Relationship between chart speed and digital recording interval (when interval is in SINGLE mode in analog and digital recording.)

Chart Speed	Spacing Between Digital Measured Value Recordings	
	1 Row	2 Rows
10 to 24mm/h	12-hr	6-hr
25 to 49mm/h	4-hr	2-hr
50 to 99mm/h	2-hr	1-hr
100 to 500mm/h	1-hr	30-min

6.10 Settings Under AUX

These are parameters which are normally left set at their initialization values, but for which capability for modification during measurement has been provided based on user requests.

These parameters divide broadly into the following. Initial values are given in parentheses ().

- 6.10.1 CLOCK Clock time-of-day adjustment
- 6.10.2 SYSTEM Recording format (TREND)
Recording mode selection (NONE)
Trend recording mode (AUTO)
- 6.10.3 PRINT FORMAT Recording ON/OFF (ON)
Logging interval specification (1 hour)
- 6.10.4 TAG Tag settings (all spaces)
- 6.10.5 MESSAGE Message settings, including TITLE (all spaces)
- 6.10.6 HEADER Header setting (all spaces)
- 6.10.7 ZONE Zone recording setting (0 to 150 mm)
- 6.10.8 PARTIAL Partial compression/expansion (OFF)
- 6.10.9 INTVL Logging interval setting
- 6.10.10 CHART Chart speed and logging interval settings to be used when
change-on-alarm or remote control is in effect.
- 6.10.11 INTERPOLATION Interpolation setting (OFF)
- 6.10.12 MOVE AVE Moving average (OFF)

6.10

6.10.1 CLOCK Setting

Press the **AUX** key to call up the starting display.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , * **F1** , **ENTRY**

AUX MODE=CLOCK

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' INTRPL MOVAVE

↓31~60 CONST

- Set the time-of-day maintained by the recorder's internal clock.
- Select CLOCK from among the selections on the LOWER DISPLAY.

Key entry : **H 8** , **I 9** , **P 0** , **K 5** , **P 0** , **M 1** ,
M 1 , **M 1** , **N 2** , **N 2** , **P 0** , * **P 0** , **ENTRY**

89/05/01 11:22:00

▶ YY/MM/DD HH:MM:SS

- Advance to the next display with the **ENTRY** key and enter the year, month, day, hour, minute and second in that order.

6.10

***** SET OK *****

DAY & TIME=89/05/01 11:22:00

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing **ENTRY** again will return you to the starting display of this mode.
- Press the **AUX** key to select setting for a different mode. To return to the data display mode, press the UPPER DISPLAY key.

6.10.2 SYSTEM Setting

For all channels, set the following:

- the recording format (in trend mode or logging mode)
- the recording mode (normal recording, change-on alarm, or print-on alarm)
- the trend mode (AUTO or FIX)

Press the **AUX** key to call up the starting display.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , * **F2** , **ENTRY**

AUX MODE=SYSTEM

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' INTRPL MOVAVE

↓31~60 CONST

- Set the recording system.
- Select SYSTEM from the selections on the LOWER DISPLAY.

(1) FORMAT Selection

Select whether to put recording into TREND (analog + digital) mode or into LOGGING (digital only) mode.

Key entry : * **F1** , **ENTRY**

FORMAT=TREND

TREND LOG

- Select either TREND or LOGGING for recording format. (initial value = TREND)

(2) Recording Mode Selection

Selects either normal mode (NONE), CHANGE ON ALARM mode, or PRINT ON ALARM mode.

- NONE Recording is started by pressing the **START/STOP** key once, and stopped by pressing it again.
- CHANGE ON ALARM ... A mode in which generation of an alarm causes chart speed and logging interval to change from their normal values to a speed and interval set up in advance for use when alarms occur. (see Section 6.10.10.)
When data is entered, the mark is displayed.
- PRINT ON ALARM A mode in which recording starts when an alarm is generated.
When data is entered, the mark displayed.

Key entry : * **F1** , **ENTRY**

ON ALARM=NONE

NONE PRINT CHANGE

- Select normal recording mode. (initial setting = NONE)
- Note: When the SET UP CNTRL demand is "EXT", if other than "NONE" is specified, an error occurs.

(3) Trend Recording Mode Selection

Determines whether trend recording mode is AUTO or FIX.

- When mode is AUTO Recording interval is determined automatically based on chart speed.

1. Trend recording interval is determined by :

$$\text{Measurement interval} \times N \leq 720 \times \frac{1}{\text{Chart Speed (mm/h)}} \\ (N = 1, 2, 3 \dots \text{integer})$$

Example : Measurement interval = 2 seconds

Chart Speed = 100 mm/h

$$\frac{720}{100 \text{ mm/h}} = 7.2 \text{ seconds}$$

From the above, the trend recording interval becomes 6.

2. If the above computation yields a result smaller than the measurement interval, the trend recording interval becomes the same as the measurement interval.

- When mode is FIX Trend recording is performed at same interval as the scan interval set in SET UP mode. See Section 6.11.2 (1) "SCAN INTERVAL Selection".

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : * F1 ENTRY

TREND= AUTO

FIX AUTO

- Set trend recording mode to AUTO.

*** SET OK ***

TREND NONE AUTO 2S

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered.
- Pressing ENTRY again will return you to the starting display of this mode.
- Press the AUX key to select setting for a different mode. To return to the data display mode, press the UPPER DISPLAY key.

6.10.3 PRINT FORMAT Setting (Individual Channel Recording ON/OFF)

This mode allows setting of three selections:

- Whether to give an analog record.
- Whether to give a logging record.
- Which of the logging interval settings to use (when "MULTIPLE" is in effect).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , * **F3** , **ENTRY**

AUX MODE=PRINT-FORM

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' INTRPL MOVAVE

↓31~60 CONST

- Perform recording related setting.
- Select PRINT from LOWER DISPLAY selections.

(1) TREND Recording ON/OFF Specification

Key entry : * **F1** , **ENTRY**

01:TREND PRINT=ON

ON OFF

- Select for one channel whether or not to perform analog recording of the measurement data.
- The initial values are set to give an analog record for all channels from 1 through 20.

(2) DIGITAL Recording ON/OFF Specification


Key entry : * **F1** , **ENTRY**

01:DIGITAL PRINT=ON

ON OFF

- Select for one channel whether or not to perform digital recording of measurement data.

Example :



- The initial values are set to give a digital record for all channels from 1 through 20.

Note : If the logging interval has been set to SINGLE with INTERVAL in SET UP mode (Section 6.11.2), the Logging Interval 1 setting in Section 6.10.9 is automatically selected. (initial value is 1 hour.) Since it is necessary to select from among the three intervals set in Section 6.10.9 only when MULTIPLE is in effect, the procedure following need be done only in that case.

(3) LOGGING INTERVAL Specification

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : * F2 , ENTRY

01:INTVL NO.=2

1 2 3

*** SET OK ***

01: TREND=ON DGTL=ON NO.=2

- Select the interval for digital recording of data for one channel. The actual times for the three intervals (when MULTIPLE is in effect) are determined by the procedure in Section 6.10.9 "LOGGING INTERVAL Setting".
- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing ENTRY again will return you to the starting display of this mode.
- To proceed to the next channel, press CH UP
△ key.
- Press the AUX key to select setting for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

6.10.4 TAG Settings

Comments (tags) can be set to be recorded instead of channel numbers. This mode sets the TAG definitions.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** * **F4** , **ENTRY**

AUX MODE=TAG

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' MOVAVE INTRPL

- This procedure sets the tag definitions.
- Select TAG from the LOWER DISPLAY.

01:TAG= _____

▶ Up to 7 Characters

- When the **ENTRY** key is pressed, the display advances to a tag entry display and the cursor appears. Up to seven characters can be entry.

Key entry : **SHIFT** , **SHIFT** , **D * T** , **SHIFT** , **A SP Q** ,
SHIFT , **G 7 W** , **M 1 .** , **N 2 #** , **0 3 %** , **J 4 z** , **ENTRY**

01:TAG=TAG1234

▶ Up to 7 Characters

- Entry the tag name.

***** SET OK *****


01:TAG=TAG1234

- The "SET OK" message is displayed to show that the settings have been accepted internally.

The LOWER DISPLAY shows the information entered.

Pressing **ENTRY** again will return you to the starting display of this mode.

Note : The selection as to whether to record the channel number or the tag name is made in the SET UP mode. (see Section 6.11.1 (1).)

- To proceed to the next channel, press **CH UP**  key.
- Press the **ENTRY** key to select setting for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

6.10.5 MESSAGE Setting

Messages can be set to print out:

- As a title of 32 characters maximum.
- Functions (16 characters) using panel keys (in FUNC KEY CALL).
- Remote controls (5 types, up to 16 characters) from the rear panel.
- Alarm messages (5 types, up to 16 characters).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , **NEXT** , * **F1** , **ENTRY**

AUX MODE=MESSAGE

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART INTRPL MOVAVE

↓31~60 CONST

- This procedure sets the message definitions.
- Select MESS from the LOWER DISPLAY line.

Key entry : **F2** , **ENTRY**

MESSAGE= PANEL

↓TITLE PANEL CONT-1 CONT-2 ← LOWER DISPLAY

↓CONT-3 CONT-4 CONT-5 ALM-1

↓ALM-2 ALM-3 ALM-4 ALM-5

- Here we enter the messages whose recording will be commanded from the front panel keys.

TITLE :	Message for title printing	CONT-5 :	Remote control message 5
PANEL :	Messages commanded from front panel key using FUNC KEY CALL command	ALM-1 :	Alarm condition 1 dependent message 1
CONT-1 :	Remote control message 1	ALM-2 :	Alarm condition 2 dependent message 2
CONT-2 :	Remote control message 2	ALM-3 :	Alarm condition 3 dependent message 3
CONT-3 :	Remote control message 3	ALM-4 :	Alarm condition 4 dependent message 4
CONT-4 :	Remote control message 4	ALM-5 :	Alarm condition 5 dependent message 5

Key entry : **Alphanumeric keys** , **ENTRY**

MSG PANEL= -

▶ UP to 16 Characters <01> ←

- Enter the message definition. (Example at left is for message whose printing is commanded from panel.)

Indicates ordinal of character being entered.

***** SET OK *****

MESSAGE TYPE = PANEL

- Setting finished.

The conditions controlling alarm message printing are set using "LOGIC" in SET UP mode. The printing conditions for ALM-1 are set using MSG-1. Similarly, MSG-2 through MSG-5 correspond to ALM-2 through ALM-5.

The following can be set as alarm conditions :

- OFF No message printout
- ALL Print the message when an alarm goes ON in any channel.
- SELECT-RELAY ID Print the message when the internal switch or relay specified by RELAY ID goes from the OFF to the ON state.


CAUTIONS

1. Title printout is in effect for trend recording only.
Panel key, remote control and alarm dependent messages are printed out with time of day (hour:minute) plus 16 characters.
2. Remote-control message printout employs edge detection (contact OFF-to-ON transition). Since detection is performed with a one-second cycle period, the contact must remain ON for at least one second.
3. Messages (title, panel key, remote control, alarm control) print only when PRINT START is in effect.
When PRINT STOP is selected, generation of a message printing request (except title) results in the message data being retained internally; the retained message data is then printed out the next time PRINT START is selected.
4. Message printout data is stored into a memory with capacity for 12 messages, and printed out in sequence. However, if numerous message requests occur in a short interval there may be times when the memory capacity is exceeded because the rate of message printout (output from memory) is slower than that the message printout request rate (input to memory).
When this occurs, the printout data corresponding to the later messages will not go into memory, and as a result those messages will not be printed.

6.10.6 HEADER Setting

The header can be used to print out comments concerning the recording prior to recording start. Up to 5 lines of 60 characters each can be printed.

Recording
example :



- Pressing the **HEADER** key on the front panel records the text defined by the entries below (five lines in all, No.1 through No. 5).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , **NEXT** , * **F2** , **ENTRY**

AUX MODE=HEADER

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY
 ↓MSG HEADER ZONE PART
 ↓INTVL CHART' INTRPL MOVAVE
 ↓31~60 CONST

- This procedure sets the header definition.
- Select HEADER from the selections on the LOWER DISPLAY line using the function keys.

Key entry : * **F1** , **ENTRY**

HEADER LINE No.=1

↓ 1 2 3 4
 ↓ 5

- Select the number of the line to be entered.
 "1" selects Line 1, "5" selects Line 5.

LINE 1=

► Up to 60 Characters <01>

↑
 Cursor position

- The display for text entry will appear.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : * **Alphanumeric keys** , **ENTRY**

LINE 1=EFGRHIJ

► Up to 60 Characters <08>

↑
Column number of the cursor position

- Enter text.
- The cursor position of the current input point is shown at the right of the LOWER DISPLAY.

This can be followed by definition entries for several more header lines.


*** SET OK ***

HEADER NO.=1

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing **ENTRY** again will return you to the starting display of this mode.
- Press the **AUX** key to select setup for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

6.10.7 ZONE Recording Setting (Recording width Setting)

"Zone recording"
means :



Zone recording makes it possible to prevent the recording traces of different channels from overlapping each other, through the definition of different recording bands (zones) for individual channels on the chart paper.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : **AUX** , **NEXT** , *** F3** , **ENTRY**

AUX MODE=ZONE

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' INTRPL MOVAVE

↓31~60 CONST

- This procedure sets a recording zone.
- Select ZONE from the LOWER DISPLAY line.

Key entry : **>** , **K 5** , *** P 0** , **ENTRY**

01:ZONE=50~150mm

▶ Zone Left=0~145mm

Channel No.

- Input recording zone settings for channel 01.
- This fixes the left boundary during analog recording. This position corresponds to the span-left value set in the range setting step.
- The LOWER DISPLAY line shows the allowable input range.

Key entry : **M 1** , **K 5** , *** P 0** , **ENTRY**

01:ZONE=50~150mm

▶ Zone Right=5~150mm

- This fixes the right boundary during analog recording. This position corresponds to the span-right value set in the range setting step. (See Section 6.7.)

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

*** SET OK ***

01: ZONE=50~150mm

* The recording zone for channel 01 has been set to the band between 50 and 150 mm.

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing ENTRY again will return you to the starting screen of this mode.
- To proceed to the next channel, press CH UP
△ key.
- Press the AUX key to select setup for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

CAUTIONS

- Allowable input ranges : $0 \leq \text{zone left} \leq 145$
 $5 \leq \text{zone right} \leq 150$
- The zone left setting must be less than the zone right setting.
- Minimum zone width is 5 mm.

6.10.8 PARTIAL Compression Recording Setting

The partial compression feature makes it possible to compress part of the recording range for differentiated recording of those parts that require detailed examination and parts that do not.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : , , ,

AUX MODE=PARTIAL

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' INTERPL MOVAVE

- This procedure sets partial compression recording.
- Select PART from the selections on the LOWER DISPLAY line.

Key entry : ,

01:PARTIAL=ON

ON OFF

- Turn ON partial compression.
- Note : When partial compression is being performed, an ON /OFF designation is required in SET UP mode (RECORD). (See Section 6.11.1 (9))

(Displayed only when PART ON)

Key entry : , ,

02:PART=20%

▶ Rate=1~99%

- Specify as a percentage that part of the zone full-span width to be compressed.

Key entry : , , , , , ,

02:BDY=0.0000V

▶ Boundary=-1.9999~1.9999V

- Set the boundary value for partial compression (must be within the channel span range, and within the scaling range also if scaling is ON.)
- Note : Input is not possible if the displayed channel is set for SKIP or DI.
- The LOWER DISPLAY shows the allowable range of input (screen shown is for 2V range).

[Key Entry, Panel Displays]

Key entry : ENTRY

*** SET OK ***

02:ON RATE:20% BDY:0.0000V

[Description]

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing ENTRY again will return you to the starting screen of this mode.
- To proceed to the next channel, press CH UP
△ key.
- Press the AUX key to select setting for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

(Normal Recording Example)




Figure 6.10.1

(Partial Recording Example)




Figure 6.10.2

(Explanation of Partial Recording)


- Figure 6.10.1 shows normal recording with a 100mm span. Here the 0V point is positioned 50 mm (50% of span) from the chart paper left margin.
(The 100mm has been set for the full span of the measured value (-6 to +6V).)
- Figure 6.10.2 shows partial compression recording with a 100 mm span. In this case the 0V point is positioned 25mm (25% of span) from the chart paper left margin.
(The 100mm has been set for the full span of the measured value (-6 to +6V).)

As can be seen from the figure, the partial compression boundary value serves as a boundary, and on the recording chart the size of the band allocated to the left side (here, the negative side) is equal to the recording span (100mm in this example) multiplied by the partial compression recording band factor (%), and the size of the band allocated to the right side (here, the positive side) is the recording span multiplied by 100 minus the partial compression recording band factor. Thus the scales differ on the left and right sides of the partial compression boundary value.


6.10.9 LOGGING INTERVAL Setting (Including Start Time)

- The logging interval is the time interval between digital recording operations.

(In Trend Recording Mode)



(In Digital Recording Mode)



The logging interval is the time interval that digital values are recorded as shown on the above charts.

- Up to three logging intervals can be set (when MULTIPLE is in effect). You can also determine individually which of those logging intervals to use for each channel. (See Section 6.10.3 (3), "LOGGING INTERVAL Specification").
- The relationships in the table below obtain depending on whether logging interval mode is SINGLE or MULTIPLE, and whether recording format is TREND or LOGGING modes.

	SINGLE	MULTIPLE
TREND	Logging interval automatically decided by the relationship between chart speed and digital recording. *1	Select one of logging intervals 1 through 3 for each individual channel.
LOGGING	All channels recorded at times set for one certain interval (Interval 1).	Select one of logging intervals 1 through 3 for each individual channel.

- *1: Use SET UP mode to transfer between SINGLE and MULTIPLE for logging intervals.
- *2: When this is automatically determined, the relationships between them are as shown in the table below.

Chart Speed	Digital Measured Value Recording Interval	
	1 Row	2 Rows
10 to 24 mm/h	12 hr	6 hr
25 to 49 mm/h	4 hr	2 hr
50 to 99 mm/h	2 hr	1 hr
100 to 1500 mm/h	1 hr	30 min

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : AUX , NEXT , NEXT , * F1 ,
ENTRY

AUX MODE=INTERVAL

↓CLOCK	SYSTEM	PRINT	TAG
↓MSG	HEADER	ZONE	PART
↓INTVL	CHART'	INTRPL	MOVAVE
↓31~60	CONST		

← LOWER DISPLAY

- This procedure sets the logging interval (s).
- Select INTVL from the LOWER DISPLAY line.

Key entry : P 0 : , P 0 : , P 0 : , * M 1 , ENTRY

INTVL1=00:01

▶ Interval=HH:MM

- Input the logging interval. Values up to 24 hr can be input. (initial setting = 1 hour.)
- If the recording mode is SINGLE, then interval setting is finished at this point and the value set for Interval 1 will become the interval for all channels.
- Intervals 2 and 3 can be set only if the recording mode is MULTIPLE.

Key entry : P 0 : , P 0 : , P 0 : , * N 2 # , ENTRY

INTVL2=00:02

▶ Interval=HH:MM

Key entry : P 0 : , P 0 : , P 0 : , * 0 3 % , ENTRY

INTVL3=00:03

▶ Interval=HH:MM

- Set interval 3 (3 minutes).

Key entry : * F1 , ENTRY

START TIME=ON

ON OFF

- Set the "Start On" time. (Recording will start at the time of day set.)
- When the start time is OFF, setting entry is no longer necessary.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : * Numeric keys , ENTRY

START TIME=89/04/01 12:00

▶ Input YY/MM/DD HH:MM

- Input the year, month, day, hour and minute at which to start.

*** SET OK ***

I1=00:01 I2=00:02 I3=00:03

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing ENTRY again will return you to the starting display of this mode.
- Press the AUX key to select setting for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

6.10.10 Setting of Chart Speed and Logging Interval Used When Change-On-Alarm or Remote Control in Effect

- The /REM option function is used for remote control.
- In change-on-alarm mode it is possible to change the chart speed and logging interval when an alarm occurs.

This procedure sets the chart speed and logging interval in effect after the change.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : , , , ,

AUX MODE=CHART'

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY
 ↓MSG HEADER ZONE PART
 ↓INTVL CHART' INTRPL MOVAVE
 ↓31-60 CONST

- This procedure sets the post-change chart speed and logging interval.

Key entry : , , , ,

CHART SP'=200mm/H

▶ Chart Speed'=1-1500mm/H

- Input the post-change chart speed.

Key entry : , , , ,

INTVL'=00:10

▶ Interval=HH:MM

- Input the post-change logging interval value (10 minutes).

*** SET OK ***

CHART'=200mm/H INTVL'=00:10

* : This function is used to enable recording data with more detail or logging data in greater quantity for a certain time period following occurrence of an alarm.

- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing again will return you to the starting display of this mode.
- Press the key to select setting for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

6.10.11 Interpolation Setting

When performing analog recording of data, the interpolation function enables data points to be linked by lateral line segments so as to show the continuity of the data.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , NEXT , NEXT , * F3 ,
ENTRY

AUX MODE=INTRPL

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY
 ↓MSG HEADER ZONE PART
 ↓INTVL CHART' INTRPL MOVAVE
 ↓31-60 CONST

- This procedure sets interpolation.
- Select INTRPL from the LOWER DISPLAY line.

Key entry : * F1 , **ENTRY**

01:INTRPL=ON

ON OFF


- Select whether or not to perform interpolation (initial setting = OFF).

*** SET OK ***

01:INTRPL=ON

- * The maximum number of channels for which INTRPL can be selected is 10. Interpolation is performed only when the trend recording interval (see Section 6.10.2 (3)) is 6 seconds or greater.

<Recording Example>



- The "SET OK" message is displayed to show that the settings have been accepted internally.
- The LOWER DISPLAY shows the information entered. Pressing **ENTRY** again will return you to the starting display of this mode.
- Press the **AUX** key to select setting for a different mode.
- To return to the data display mode, press the UPPER DISPLAY key.

6.10.12 Moving Average Setting

Select whether or not to perform a moving average on the measured data.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : **AUX** , NEXT , NEXT , * F4 ,
ENTRY

AUX MODE=MOV-AVE

↓CLOCK SYSTEM PRINT TAG ← LOWER DISPLAY

↓MSG HEADER ZONE PART

↓INTVL CHART' INTRPL MOVAVE

↓31~60 CONST

- This procedure performs moving average setting.

Key entry : * F1 , **ENTRY**

01:MOVE AVERAGE=ON

ON OFF

- Select whether or not to perform moving average on channel 1 (initial setting = OFF).

***** SET OK *****

01:MOV-AVE=ON

(Specifications)

Moving average is performed over 8 scans of data.


- ※ For each channel, the 8 oldest scans of data are deleted, the updated data are stored in the buffer memory, and then, 8 new scans of data are computed and recorded.

(Reason for Use)

If there is jitter in the measured signal, it can be suppressed in the final measurement result by computing a moving average.


Notes :

1. If the input goes over-range in the plus or minus direction, the data for that scan is replaced by +OVER = 32382 (7E7EH) or -OVER = -32383 (8181H) in the moving average computation.
2. Processing at measurement start :

**Example :**


When measurement result on first scan is 10 mV :

①



Measurement result on second scan = 20 mV :

②



③

6.11 Changing SET UP (Basic Pre-Use Recorder Specifications)

Although the SET UP parameters normally do not require change, you may need to refer to this section when adding options or modifying functions to fit an application.

These parameters cannot be changed during operation and measuring

(Entering SET UP Mode)

1. Set DIP switch No. 1 in the back of the recorder to ON.




Figure 6.11.1

2. Hold the UPPER DISPLAY key on the operation panel depressed and turn power ON.
Display below appears.

SET UP MODE=RECORD

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

6.11

CAUTION

- Continue with each setting procedure until the "*** SET ***" indication appears.
- If DIP switch No. 1 is OFF, the recorder will display the message below and HOLD until the DIP switch is set to ON.

REFUSE SET UP ENTRY

Please set DIP SW No.1

SET UP Summary**RECORD (Recording Related SET UP) - - - Section 6.11.1**

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
TAG/CH	Selects whether tag name or channel number will be displayed/recorded on panel and recording chart.	TAG CH	CH
SCALE	Selects spacing of divisions on scale recorded on chart.	A (0, 100%) B (Every 20%) C (0, 50, 100%) OFF	A
DIGITAL PRINT	Specifies number of digits for left-end digital values during trend recording.	1 (digit) 2 (digit)	1 (digit)
CH PITCH	Selects channel number recording spacing during trend recording.	12.5 (mm) 5.0 (mm)	12.5 (mm)
TITLE PITCH	Selects spacing between each TITLE recording during trend recording.	1500 (mm) 600 (mm)	1500 (mm)
LOG FORMT	Selects whether to print logging recordings vertically or horizontally on chart.	HORI (Horizontal) VERT (Vertical)	HORI
SPEED PRINT	Selects whether or not to record speed information when chart speed changes.	ON OFF	ON
ON/OFF MARK	Selects whether or not to record recording start time on chart.	ON OFF	ON
PARTIAL	Selects whether or not to perform partial compression recording.	ON OFF	OFF
ALARM PRINT	Selects whether or not to print occurrence and release of alarms.	ON OFF	ON
TIC	Selects whether or not to print TIC (scale recording position).	ON OFF	OFF
INTEG OVER	Select whether to hold or reset integrator values to 0 on count up. (When using computation option).	RESET HOLD	RESET
MATH ERROR	Selects whether to set computation result to "+OVER" or "-OVER" value when error occurs in computation (option).	-OVER +OVER	+OVER

6.11**INTERVAL (Interval Related SET UP)**

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
SCAN	Decides the interval between scans.	2, 3, 4, 5, 6, 10, 12, 15, 20, 30, 60	2 (second)
LOG INTVL	Logging interval setup	SINGLE MULTI	SINGLE

ALARM, Communication, IC Memory Card and Remote Control Related SET UP (CONTROL)

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
REFLASH	Selects whether or not to set realarm on repeat of failure.	ON OFF	OFF
AND RLY INT	Selects whether to use AND or OR on relay output (internal relays).	NONE I01, I02	NONE
AND RLY SWT	Selects whether to use AND or OR on internal switch (internal switches).	NONE S01 to S10	NONE
INT ALM	Selects whether to energize or de-energize internal alarm output relays.	ENERG DE-EN	ENERG
COMMAND	Selects either internal (alarm) or external (remote control option) command type for recording start/stop control.	TRIG LEVEL	TRIG
DEMAND	Selects whether to perform CHANGE ON and PRINT ON on alarm or on remote controls from external source.	INT EXT	INT
ALARM ACK	Selects whether to enable or disable front panel ALARM ACK key.	ON OFF	OFF
RELAY HOLD	Selects hold or non-hold operation for alarm output relays.	ON OFF	OFF
RH TIME	Selects interval time to be used when an ascending rate-of-change alarm is set.	1 (SCAN) to 15 (SCAN)	1 (SCAN)
RL TIME	Selects interval time to be used when an descending rate-of-change alarm is set.	1 (SCAN) to 15 (SCAN)	1 (SCAN)
ALARM HYS	Sets alarm hysteresis in %.	0.0% to 1.0%	0.5%
DGTL PRINT	Selects whether to perform digital print commands according to internal settings (INT) or remote control (EXT).	EXT INT	INT
COMM INPUT	Selects whether or not to use channels 31 through 60 for digital communications input.	ON OFF	OFF
MEM INPUT	Selects whether or not to use channels 31 through 60 for memory playback.	ON OFF	OFF

BURN OUT Related SET UP (BURN)

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
BURN OUT	Selects whether to force measurement result to "+OVER" or "-OVER" on burnout.	UP DOWN	UP
BURN	Selects whether or not to perform burnout processing in recorder.	ON OFF	ON

GROUP SET UP

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
G1 to G6	Specifies which channels are to be assigned to which groups.	1 to 20 31 to 60	G1=01 to 10 G2=11 to 20 G3=01 to 15 G4=01 to 20 G5=31 to 60 G6=01 to 60

LOGICAL SET UP

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
LOGICAL	Sets operating conditions for PRINT ON ALARM and CHANGE ON ALARM, etc.	START STOP MAN PRINT DIGITAL CHNG SPEED MSG 1 to 5	_____
TRIGGER MODE	Displays Relay ID only during SELECT.	OFF ALL SELECT	OFF All for START STOP CHNG SPEED
RELAY ID	Set Relay ID.	I01, I02 S01 to S10	_____

KEY LOCKOUT SET UP

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
START STOP KEY	Selects whether or not key is enabled during KEY LOCK.	LOCK FREE	LOCK
HEADER KEY		LOCK FREE	LOCK
LIST KEY		LOCK FREE	LOCK
MAN PRINT KEY		LOCK FREE	LOCK
CHART FEED KEY		LOCK FREE	LOCK
ALM ACK KEY		LOCK FREE	LOCK
ALM RESET KEY		LOCK FREE	LOCK

RJC SET UP

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
RJC MODE	Selects whether to use internal settings or external settings for reference junction compensation values.	INT (internal setting) EXT (external setting)	INT (internal setting)
RJC VOLT	Sets reference junction compensation value. (Displayed only for EXT)	Numeric value input	

Recording Color SET UP (COLOR)

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
COLOR	Specifies the recording color for each channel.	PURPLE RED GREEN BLUE BROWN BLACK NAVY YEL - GREEN RED - PURPLE ORANGE	Distributed over all channels.

Temperature Display °C/°F SET UP

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
TEMP UNIT	Switches between °C and °F temperature display.	°C °F	Set at installation.

Printer Adjustment SET UP

Parameter	Description	Setting Range	
		Setting Items	Initial Setting
HYS	Printer recording vertical direction adjustment	-100 to 100	1
ZERO	Printer left side specification	0 to 4000	_____
FULL	Printer right side specification	0 to 4000	_____
PRINT ESC	Leave the printer adjustment menu	YES NO	_____

6.11.1 Recording Related SET UP (RECORD)

Set DIP switch No. 1 in the back of the recorder to ON, and while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

On entering SET UP mode, the display will first show the screen below.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : * F2 , ENTRY

SET UP MODE=RECORD

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- This procedure sets recording related SET UP parameters.
- Select RECORD from the selections on the LOWER DISPLAY line.

(1) Channel Printing, Tag Printing Selections

Key entry : * F2 , ENTRY

CH OR TAG=CHANNEL

TAG CH

- Select whether to use channel numbers or the specified tag names for display and printing.
(initial setting = CH)

(2) Scale Printing Selection

Key entry : * F2 , ENTRY


SCALE=EVERY 20

A B C OFF

- Select spacing for scale printing.
(initial setting = A)

A Prints 0% and 100%.
 B Prints every 20%.
 C Prints three positions : 0%, 50%, and 100%
 OFF Does not print scale.

(Example for B)



* : Specifications differ depending on whether partial compression is ON or OFF.

(When partial compression is OFF)

- Every 20% Setting is permitted only when recording width is 150mm ; when 149mm or less, 0 or 100% printing results. If 49 mm or less, printing is not performed, and printing steps to the next channel.
- 0, 50, 100% Setting is permitted only when the recording width is 100mm or greater; when 99mm or less, 0 or 100% printing results. If 49mm or less, printing is not performed, and printing steps to the next channel.
- 0, 100% Setting is permitted only when the recording width is 50mm or greater; if 49mm or less, printing is not performed, and printing steps to the next channel.

(When partial compression is ON)

- When recording width is 100mm or greater, printing is performed at three locations : left end, line segment, and right end.
- When recording width is 50 to 90mm, printing is performed at two locations : left end and right end.
- When recording width is 49mm or less, printing is not performed, and steps to the next channel.

(3) Selection of Number of DIGITAL Recording Columns for TREND Recording
[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry : * F1 , **ENTRY**

DIGITAL PRINT=1-CLMN

1-CLMN 2-CLMN 3-CLMN 4-CLMN

- Set the number of columns for digital recording. (initial setting = CLMN1)


(4) CHANNEL No. Printing Pitch Selection

Key entry : * F2 , **ENTRY**

CH PITCH=12.5mm

5.0mm 12.5mm

- Set the spacing between channel number printout pitch in trend recording. (initial setting = 12.5mm)




(5) TITLE Printing Spacing Selection

Key entry : * F2 , **ENTRY**

TITLE PITCH=1500mm

600mm 1500mm

- Set the spacing between printouts of the message set up in Section 6.10.5 (TITLE). (initial setting = 1500mm)



(6) Vertical/Horizontal Recording Direction Selection for LOGGING Recording

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry : F2 , **ENTRY**

LOG FORMAT=HORIZON

VERTI HORI

- HORI Horizontal direction
- VERTI Vertical direction

- Select whether recording will be done in horizontal direction or vertical direction during logging recording.
(initial setting = HORI)

(7) Speed Printout on CHART SPEED Change

Key entry : F2 , **ENTRY**

SPEED PRINT=OFF

ON OFF

- Select whether or not to print speed on chart when chart speed is changed.
(initial setting = ON)




Chart speed after change


(8) Marking Recording Selection

Key entry : F2 , **ENTRY**

ON/OFF MARK=OFF

ON OFF

- Select whether to print time-stamp marking on chart when recording starts.
- Effective only in trend mode.
(initial setting = ON)



(9) Partial Compression Recording Selection

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: F2 , **ENTRY**

PARTIAL=OFF

ON OFF

- Select whether or not to perform partial compression. (initial setting = OFF)

※ The areas to be subjected to partial compression are set up by the procedure described in Section 6.10.8.


(10) ALARM PRINT ON/OFF Selection

Key entry: F2 , **ENTRY**

ALARM PRINT=OFF

ON OFF

- Select whether to perform printout on alarm occurrence and release. (initial setting = ON)


**(11) TIC (SCALE Printout Position) PRINT ON/OFF**

Key entry: F2 , **ENTRY**

TIC=OFF

ON OFF

- Select whether to print tic marks to indicate exact positions of scale values printed on chart. (initial setting = OFF)



(12) Handling When Internal Computation Reaches Maximum Value

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: * F1 , **ENTRY**

INTEG OVER=RESET

RESET HOLD

- Select whether to be reset or held to ZERO when counting-up occurs during computation summing up (TLOG SUM). (initial setting = RESET)

※ Computation range is $\pm 30,000$.

(13) Selection of Printout for Computation (MATH Option) Error

Key entry: * F2 , **ENTRY**

MATH ERROR=+OVER

-OVER +OVER

- Select whether to set computation result to "+OVER" or to "-OVER" when error occurs in internal computation (31 and up). (initial setting = +OVER)

Key entry: **ENTRY**

*** RECORD SET ***

- SET UP completes.

6.11.2 INTERVAL Related SET UP (INTVL)

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

On entering SET UP mode, the display will first show the screen below.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: * F3 , ENTRY

SET UP MODE=INTERVAL

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- This procedure sets interval related SET UP parameters.
- Select INTVL from the selections on the LOWER DISPLAY line.

(1) SCAN INTERVAL Selection (2 to 60 Seconds)

Key entry: F1 , ENTRY

SCAN=2

↓2 3 4 5

↓6 10 12 15

↓20 30 60

- Select the interval between scans. (initial setting = 2 sec)

- ※ In the case that FIX mode was selected in the trend recording mode selection (Section 6.10.2(3)), the scanning interval selected here determines how many seconds the trend recording interval will be.
- ※ In the case that 100ms has been selected as the A/D integration time (see Section 3.2, "Recorder Main Unit DIP Switches"), select from 6 to 60 seconds.

(2) Logging Interval Mode Selection

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: F1 , **ENTRY**

LOG INTVL=SINGLE

SINGLE MULTI

- This procedure selects the logging interval mode.
(initial setting = SINGLE)

- SINGLE ... (During Trend Recording)
Measured value digital recording interval is determined automatically according to chart speed and number of lines of digital recording.
(During Logging Recording)
There is a single logging recording interval (which can be set at from 1 minute to 24 hours) which applies to all channels.
- MULTI (During Trend Recording)
Measured value digital recording can be done with any of three intervals (which can be set at from 1 minute to 24 hours individually).
(During Logging Recording)
Logging recording can be done with any of three intervals.

Key entry: **ENTRY**

*** INTERVAL SET ***

- Setting completes.

6.11.3 Alarm, Communications, IC Memory Card and Remote Control Related SET UP (CONTROL)

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

On entering SET UP mode, the display will first show the screen below.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT , F1 , ENTRY

SET UP MODE=CONTROL

↓P-ADJ RECORD INTVL END ← LOWER DISPLAY

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- This procedure sets alarm, communication input, IC memory card, and remote control related SET UP parameters.
- Select CONTROL from the selections on the LOWER DISPLAY line.

(1) Selection for Reflash on New Alarms


Key entry: F2 , ENTRY

REFLASH=OFF

ON OFF

- Selects whether or not to provide "reflash" on internal special output relays (option).
ON : Reflash alarm mode
OFF : No reflash alarm mode

※ "Reflash" is a function used to indicate repeating alarm occurrences among a group of alarms sharing a special output relay.



(2) ALARM Relay Output AND/OR Selection

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: F3 , **ENTRY**

AND RLY INT=I01~I02

↓NONE I01 I01~02

- Select the internal relays which will output with a logical AND function.
(initial setting = NONE, meaning all OR output)

Key entry: F3 , **ENTRY**


AND RLY SW=S01~S02

↓NONE S01 S01~02 S01~03

↓S01~04 S01~05 S01~06 S01~07

↓S01~08 S01~09 S01~10

- Select the internal switches which will output with a logical AND function.
(initial setting = NONE, meaning all OR output)



CAUTION

Precautions to observe when specifying AND output for an alarm relay.

- The logical AND function does not affect alarm printing. As with any other alarm, printing is performed individually for each alarm occurrence.
- Since both the internal alarm output relays and the internal switches are divided midway into AND group and OR group, it is not possible to freely intermix AND and OR output relays.

(3) Internal ALARM Relay Output Energize / De-Energize Selection

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: * F1 , ENTRY

INT ALM=ENERGIZE

ENERG DE-EN

- Select whether internal alarm relays energize or de-energize on alarm.
 { ENERG ... Energizing type
 DE-EN ... De-energizing type
 (initial setting = ENERG)

(4) Recording Start/Stop Control and Internal (Alarm) or External (Remote Control Option) Command Format (Trigger or Level) Selection

Key entry: F2 , ENTRY

COMMAND=TRIGGER

LEVEL TRIG

- Select whether to use trigger or level format for recording control by internal (alarm) or external (remote control option) sources.
 (initial setting = TRIG)

Trigger (TRIG) .. Recording started by internal (alarm) or external (remote control) requests, but stopped by START/STOP key.

Level (LEVEL) .. Recording start and stop both performed according to internal (alarm) or external (remote control) requests.

(5) Selection of Whether to Perform Change On (Chart Speed Interval Change) and/or Print ON (Recording ON/OFF) with External Remote Control or with Alarms

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: * F1 , **ENTRY**

DEMAND=INT

INT EXT

- { INT Internal command (alarm)
 EXT Remote control (option) based command
 ※ When EXT is selected, "Print ON and Change ON" can no longer be selected at "ON ALARM" in the **AUX** SYSTEM mode.

- Select whether to perform change on (chart speed and logging interval change) and/or print on (recording start/stop) based on external remote control (contact input) or based on internal commands (alarms).
(initial setting = INT)

(6) Front Panel ALARM ACK Key Enable/Disable Selection

Key entry: F1 , **ENTRY**

ALARM ACK=ON

ON OFF

- ON When an alarm occurs, the alarm indicator begins flashing (flashing continues even if the alarm recovers).
Pressing the ALARM ACK key causes the indicators to show the current alarm status. (Alarm in progress ... ON, alarm recovered OFF)
- OFF When an alarm occurs, the alarm indicator turns ON. When the alarm recovers, the indicator turns OFF. The ALARM ACK key is disabled and has no effect on operation.

- Select whether to enable or disable acknowledge operations on front panel alarm indications and alarm output relays via the ALARM ACK key.
(initial setting = OFF)

(7) ALARM Relay Output Hold / Non-Hold Selection

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * F1 , ENTRY

RELAY HOLD=ON


ON OFF

- Select whether or not to hold alarm output relays on until reset.
(initial setting = OFF)

(When ON)


Once turned ON, output relay remains ON even if alarm turns OFF.

(Relays are turned OFF by pressing front panel ALARM RESET key.)



(When OFF)

Output relay turns ON and OFF together with alarm.



(8) Scan Interval Selection for Rate of Change (RH, RL) Settings

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * F1 , ENTRY

RH TIME=1

↓1	2	3	4
↓5	6	7	8
↓9	10	11	12
↓13	14	15	

- Select interval setting for rate-of-change limit alarm on increase.
- The numbers on the LOWER DISPLAY line are the numbers of scans. (initial setting = 1)

Key entry: * F1 , ENTRY

RL TIME=1

↓1	2	3	4
↓5	6	7	8
↓9	10	11	12
↓13	14	15	

- Select interval setting for rate-of-change limit alarm on decrease. (initial setting = 1)

(9) ALARM Hysteresis Selection (For High (H) and Low (L) Limit Alarms)

Key entry: * F1 , ENTRY


ALARM HYS=0.0%

↓0.0	0.1	0.2	0.3
↓0.4	0.5	0.6	0.7
↓0.8	0.9	1.0	

- Determine to what percentage of recording span to set the alarm hysteresis.
- Note: Hysteresis for rate-of-change alarms (RH, RL) and difference alarms (dH, dL) is fixed at 0% regardless of this hysteresis setting. (initial setting = 0.5%)

<Alarm Hysteresis Operation> (high limit alarm)

The alarm hysteresis is the difference between the levels of alarm generation and release.



(10) Digital Recording Control Selection

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * F2 , **ENTRY**

DGTL PRINT=INT

EXT INT

- Select whether to execute the digital print command at the pre-set interval (INT) or under remote control via a contact input and output (EXT).
Effective in trend mode only.
(initial setting = INT)

(11) Communications Input (31 to 60) ON/OFF

Key entry: * F2 , **ENTRY**

COMM INPUT=OFF

ON OFF

- Select whether or not to perform communications input using channels 31 through 60.
(initial setting = OFF)

(12) IC Memory Card Input (31 to 60) ON/OFF

Key entry: * F2 , **ENTRY**

MEM INPUT=OFF

ON OFF

- Selects whether or not to perform IC memory card input using channels 31 through 60.
(initial setting = OFF)

*** CONTROL SET ***

- SET UP is completed.

6.11.4 Key Lockout SET UP

This SET UP mode enables you to specify which keys will be operative ("free") even when the KEY LOCK is on.

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT, * F2, ENTRY

SET UP MODE=KEY-LOCK

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- The initial SET UP mode display appears.

Key entry: * F2, ENTRY

START STOP KEY=LOCK

FREE LOCK

- Select whether the START/STOP key will be locked or free when the key lock is on. (Initial setting = LOCK)

Key entry: * F2, ENTRY

HEADER KEY=LOCK

FREE LOCK

- Select whether the HEADER key will be locked or free when the key lock is on. (Initial setting = LOCK)

Key entry: * F2, ENTRY

LIST KEY=LOCK

FREE LOCK

- Select whether the LIST key will be locked or free when the key lock is on. (Initial setting = LOCK)

Key entry: * F2, ENTRY

MAN PRINT KEY=LOCK

FREE LOCK

- Select whether the MAN PRINT key will be locked or free when the key lock is on. (Initial setting = LOCK)

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * F2 , ENTRY

CHART FEED KEY=LOCK

FREE LOCK

- Select whether the CHART FEED key will be locked or free when the key lock is on. (Initial setting = LOCK)

Key entry: * F2 , ENTRY

ALM ACK KEY=LOCK

FREE LOCK

- Select whether the ALARM ACK key will be locked or free when the key lock is on. (Initial setting = LOCK)

Key entry: * F2 , ENTRY

ALM RESET KEY=LOCK

FREE LOCK

- Select whether the ALARM RESET key will be locked or free when the key lock is on. (Initial setting = LOCK)

*** KEY SET ***

- Pressing ENTRY , F4 (END), ENTRY takes the recorder out of SET UP mode and shows the same display as when power is turned ON. (measuring mode)

6.11.5 Burnout Related SET UP (BURN)

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry NEXT, * F4, **ENTRY**

SET UP MODE=BURN OUT

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- The initial SET UP mode screen appears.

Key entry F2, **ENTRY**

BURN OUT=UP SCALE

DOWN UP

- Select whether to set the measurement result to "+OVER" or to "-OVER" when a burnout occurs.

Key entry F1, **ENTRY**

01:BURN=ON

ON OFF ESC

- Select whether or not to perform burnout processing for TC (thermocouple) inputs.

Key entry **ENTRY**

*** BURN SET ***

- Pressing **ENTRY**, F3 (ESC), **ENTRY**, F4 (END), **ENTRY** takes the recorder out of SET UP mode and shows the same display as when power is turned ON. (measuring mode)

6.11.6 Group SET UP

This SET UP changes the channels included in the individual groups.

☆ In the initial setup, the channels are assigned to the individual groups as shown below.

G1=01 to 10	G4=01 to 20
G2=11 to 20	G5=31 to 60
G3=01 to 15	G6=01 to 60
(21 to 30 omitted)	

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT, NEXT, * F1, ENTRY

FUNC=GROUP

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- Perform a group setting.

Key entry: Numeric keys, ENTRY

GROUP1(G1)=01~10

▶ First-Last CH For Group

- Specify the channels to be assigned to Group 1.
- Following this, the remaining groups to Group 6 can be set in the same manner.

※ First channel No. must be less than the last channel No.

Key entry: Numeric keys, ENTRY

GROUP1(G4)=01~20

▶ First-Last CH For Group

Key entry: ENTRY

*** GROUP SET ***

- Group SET UP is completed.
- Pressing ENTRY once more returns the display to the first display pressing F4 (END) and then ENTRY takes the recorder out of SET UP mode.

6.11.7 Logic SET UP

(Set mainframe operation during print-on/change alarm activation)

This SET UP selects the actuating conditions for print-on-alarm and change-on-alarm. It also turns ON and OFF manual print and message print on alarm occurrence, and selects the conditions which will actuate them.

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key depressed, turn ON the recorder power.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT , NEXT , * F2 , ENTRY

SET UP MODE=LOGIC

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

Key entry: * F2 , ENTRY

MODE=MAN PRINT

↓START MAN-P DGTL SPEED

↓MSG-1 MSG-2 MSG-3 MSG-4

↓MSG-5

- Select the actuating conditions for print-on-alarm and change-on-alarm, and turns ON and OFF manual print and message print on alarm occurrence and selects the conditions which will actuate them.

START STOP ... Selects condition for print-on-alarm.
 MAN PRINT ... Turns manual print start ON/OFF and selects condition.
 DIGITAL Turns digital recording start ON/OFF and select condition.
 SPEED Selects condition for change-on-alarm.
 MSG Turns message print start ON/OFF and selects condition.

Key entry: * F1 , ENTRY

TRIGGER MODE=OFF

OFF ALL SELECT

- Relay ID screen is displayed only when trigger mode is set to SELECT.
- There is no "OFF" on the START STOP or SPEED.

OFF Does not start operation even if alarm occurs.
 ALL Starts operation when even one alarm occurs.
 SELECT Starts operation when relay specified by RELAY ID goes from OFF to ON.

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: ,

- Specify relay number when SELECT chosen.

I** Internal alarm

S** Internal switch

- Trigger mode cannot be set to OFF for PRINT or SPEED. Choose either ALL or SELECT

Key entry:

- Logic SET UP is completed. Pressing , (END), takes the recorder out of SET UP mode and shows the same display as when power is turned ON.

CAUTION

- (1) DIGITAL Effective only when digital recording control selection (Section 6.11.3 (10) in SET UP mode) is "EXT" in trend mode.
- (2) The MSG-1 selection becomes the print start condition selection for "ALM-1" in the message setup of Section 6.10.5. Similarly, MSG-2 through MSG-5 become the condition selections for ALM-2 through ALM-5, respectively.

6.11.8 RJC SET UP

This SET UP selects whether to use internal or external reference junction compensation values.

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT, NEXT, F3, ENTRY

SET UP MODE=RJC

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- Select reference junction compensation related setup.

Key entry: F1, ENTRY

01:RJC=INT

EXT INT ESC

- Determine whether to perform reference junction compensation based on internal data or an external setting.

INT Uses recorder internal reference junction compensation circuit.

EXT Inputs voltage value to use as reference junction compensation value.

(Input only when EXT is selected.)

Key entry: Numeric entry, ENTRY

01:RJC VAL= 0 μ V

▶ Limit -20000~20000 μ V

- Input voltage to use for reference junction.
(Must be within range -20000 μ V to +20000 μ V.)

*** RJC SET ***

- RJC setup is completed.
- Pressing ENTRY once more returns the display to the first display; pressing F4 (END) and then ENTRY returns the recorder to normal mode.

6.11.9 Recording Color SET UP (COLOR)

The colors to be used for trend recording can be set individually for each channel.

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT, NEXT, F4, ENTRY

SET UP MODE=COLOR

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- Select colors.

Key entry: F1, ENTRY

01:COLOR=PURPLE

↓PURPLE RED GREEN ESC

↓BLUE BROWN BLACK NAVY

↓YEL-GR RED-PR ORANGE

- Specify color for channel No.1.
To specify colors for other channels, change the channel number with CH UP and CH DOWN.

Note: The initial settings are, in order from channel 1, purple, red, green, blue, brown, black, navy, blue yellow-green, red-purple, and orange.

Key entry: ENTRY

*** COLOR SET ***

- Press ENTRY key again, then press F4 key (ESC), ENTRY key, F4 key (END), and ENTRY key to release from SET UP mode.

6.11.10 °C/°F Temperature Display SET UP (only for /DF model and models available in North America)

Set DIP switch No. 1 in the back of the recorder to ON and, while holding the UPPER DISPLAY key pressed, turn ON the recorder power.

On entering the SET UP mode, the display unit will first show the screen below.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: NEXT , NEXT , NEXT , F1 , ENTRY

SET UP MODE=TEMP-SET

↓P-ADJ RECORD INTVL END

↓CNTRL KEY COMM BURN

↓GROUP LOGIC RJC COLOR

↓TEMP

- Selects either °C or °F for temperature display.

Key entry: F1 , ENTRY

TEMP UNIT=°C

°C °F

- Select the temperature unit.

Key entry: ENTRY

*** TEMP SET ***

- Setting is complete.
- Pressing ENTRY again, and then F4 and ENTRY takes the recorder out of the SET UP mode.

Note: The following settings are initialized whenever temperature display is changed.

- All parameter settings except those of SET UP mode
- Groups within SET UP and RJC voltage values for RJC EXTERNAL

6.12 Function Call (FUNC) SET UP

Pressing the **FUNC** key on the front panel gives the display shown below, and starts the operation described in the following.

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: **FUNC**

FUNC=SET UP-LIST ON

↓SL-ON SL-OFF MSG-P ESC

↓INIT A-INIT M-INIT I-RST

- (1) SL-ON Prints out a list of the details set up in the SET UP mode.
- (2) SL-OFF Stops printout of a list of the details in the SET UP mode.

<Set Up Mode List Printout Example:>

SET UP LIST										
RECORD		CH or TAG CHANNEL		SCALE EVERY 20		DIGITAL PRINT 1-CLMN		CH PITCH 5.0mm		
		TITLE PITCH 600mm		LOG FORMAT HORIZON		SPEED PRINT ON		ON/OFF MARK ON		
		PARTIAL ON		ALARM PRINT ON		TIC OFF		INTEG OVER RESET		MATH ERROR OVER
INTERVAL		SCAN 2sec		LOG INTVL MULTIPLE						
0	1	2	3	4	5	6	7	8	9	10
CONTROL		REFLASH OFF		AND RLY INT I01P02		AND RLY SW NONE		INT ALM ENERGIZE		COMMAND TRIGGER
		DEMAND INT		ALARM ACK ON		RELAY HOLD OFF		RH TIME 1		RL TIME 1
		ALARM HYS 0.5%		DGTL PRINT INT		COMM INPUT OFF		MEM INPUT OFF		
KEY LOCK		START STOP LOCK		HEADER LOCK		LIST LOCK		MAN PRINT LOCK		CHART FEED LOCK
		ALM ACK LOCK		ALM RESET LOCK						
COMM-SET		GPIB MODE ADDRESSABLE		ADDRESS						
10	9	8	7	6	5	4	3	2	1	0

6.12

- (3) MSG-P Prints out message (PANEL).
- (4) INIT Initializes all the details already set up.
- (5) A-INIT Clears alarm printing memory.
- (6) M-INIT Clears message printing memory.
- (7) I-RST Clears interval information.

All of these are set by the function keys F1 through F4, and executed by the **ENTRY** key.

6.12

7. IC MEMORY CARD

7.1 Outline

7.1.1 Background

In order to use the memory functions described in this section, you must use a YOKOGAWA IC Memory Card. Please procure a YOKOGAWA IC Memory Card.

The memory functions discussed here comprise functions to store measured data, parameter setting values, communication input data, and computed data (when /MATH option installed).

By using the parameter setting value memory function to save range and setting information to an IC memory card, you can re-use a set of previously employed measurement conditions whenever needed just by inserting that card into the recorder.

The data memory function can be used to start data acquisition on alarm occurrences, chart end, external contact inputs, or memory setting completion.

The data stored in memory can of course be recorded on the chart when necessary, and also be output via communications.

A write protect switch (No. 4) is provided to prohibit the writing to the IC memory card. (See Section 3.2 "Recorder Main Unit DIP Switches".)

7.1.2 Specifications

Functions	: Setting value and data memory
Format	: IC memory card
Memory capacity	: 64K bytes, or 256K bytes or 512K bytes
Sampling modes	: Free mode ; Start via manual Trigger mode ; Start via trigger conditions
Sampling rate	: Scan interval selected for recorder, plus 1/2/5/10 minutes
Data length	: 0.5K, 1K, 2K, 4K, 8K, 16K, 32K data samples per channel, selection common to all channels
Data capacity	: 2 bytes per data
Sampled channels	: Individually specified for each channel.

Trigger conditions

1. Data write

- Alarm detection : Select relay No. or switch No. of alarm trigger in data write mode.
When the alarm occurs, the triggering condition is satisfied when the specified relay or switch goes from OFF to ON.
- Chart end detection : Triggering condition satisfied when chart end is detected.
- External contact input : Triggering condition satisfied when contact input turns ON, if recorder has optional remote (/REM) function.

2. Data Read

- Alarm detection : Select relay No. or switch No. of alarm trigger in data read mode.
When the alarm occurs, the triggering condition is satisfied when the specified relay or switch goes from OFF to ON.
- External contact input : Triggering condition satisfied when contact input turns ON, if recorder has optional remote (/REM) function.

* Monitoring for external contact input triggering detection is performed once each second. Therefore, the ON time of the external contact input must be at least one second.
Alarm and chart end detection is done at each measurement interval.

- Pre-trigger : Can be set from 0 to 100% in 10% increments.
- Memory data : Parameter setting values
Measured data (including computed data)
Communications input data (when /GP-IB, /RS-232C in use)
- Output : Chart recording; Data output rate output time interval
Communications output (when /GP-IB, /RS-232C in use);
ASCII and binary output
- Battery backup : Lithium battery (life approximately 4 years) ...for 64K bytes
(life approximately 2 years) ...for 256K bytes
(life approximately 2 years) ...for 512K bytes

7.1.3 Battery Installation / Replacement

This section describes how to install or replace the IC memory card memory data protection battery.

A battery should always be installed when using the card.

- (1) Hold the IC memory card with its part number label side on top.
 - (2) Catch the side of the battery holder with your fingernail and pull out to remove the holder (Figure 7.1).
 - (3) Insert new batteries B9586JU (for 3789 03, 64K bytes), B9586JV (for 3789 04 and 3789 05, 256K bytes, 512K bytes) into the holder.
 - (4) Insert the battery holder into the IC memory card.
Thus, the new battery has been loaded. Also, the battery can be replaced in accordance with the following.
 - (5) If CARD BAT is displayed when the memory card is in use, replace the battery.
 - (6) Keep the power turned ON and the IC memory card installed in the recorder when replacing the battery. If the power is turned OFF or the card is removed from the recorder when the battery is being replaced, all information in the card will be lost, so exercise care.
 - (7) Catch the battery holder on the right side of the IC memory card with your fingernail and pull out the battery holder.
 - (8) Replace with a new battery, and re-insert the battery holder into the IC memory card.
- The above completes the replacement.




Figure 7.1

7.1.4 Introduction to the Setting Screen

Pressing the front panel **MEMORY** key displays the setting screen.

[Key Entry, Panel Displays]

MEMORY=SET			
↓SET	WRITE	READ	INFO
↓INIT			

Menu Name	Function
SET	Used to load and save panel setting values.
WRITE	Used to set conditions for measured data write (sampling) and execute write operations.
READ	Used to set conditions for output of measured data (sampled data) and execute recording operations.
INFO	Used to display VOLUME NAME and usable memory capacity in memory card.
INIT	Used to initialize memory cards.

7.1.5 Initialization

An IC memory card must always be initialized before it is used for the first time. A volume name of up to six characters identifying the user name or experiment can be entered when the IC memory card is initialized.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: , , ,

MEMORY=INITIALIZE

↓SET WRITE READ INFO

↓INIT

- IC memory card initialization screen.

Key entry: * ,

VOLUME=

► Up to 6 Characters

- Enter the volume name.
(Up to six characters)

Key entry: * ,

INIT OK=YES

NO YES

- If it is OK to initialize this card, verify that the IC memory card is properly inserted in the drive and press the key.


Key entry:

*** INIT OK ***

CAUTION

Although adhesive labels are provided on which to write IC memory card volume and file information, these should never be placed over the grounding surface in the middle of the card rear surface.

Placing a label over this area will defeat its static electricity protection effect and may cause loss of the data stored in the card.



7.1.6 Background Information to Know Before Setting

(1) An IC memory card can store panel setting value files in as well as measured data files. The maximum number of files which can be stored is 48 files, including both measured data and panel setting value files. One of these 48 files is used as a volume information file.

(2) About File Capacity

Of the IC memory card capacity, 3.5K bytes is dedicated to file management. Thus in the case of the type having a nominal 256K byte usable area, the maximum capacity is 252.5K bytes (508.5K bytes for a 512K byte type). Panel setup values consume 20K bytes / file. Subsection (3) shows how to compute measured data file sizes.

(3) Measured data file size estimates are obtained as follows.

$$\frac{([\text{Sampled data length}] \times 2) \times [\text{No. of sampled channels}]}{\text{No. of bytes}} + \frac{256 + 64 \times \text{No. of sampled channels}}{\text{File header information data length}}$$

- * Sampled data length : Data length specified by sample length.
- * No. of sampled channels : Number of channels which have been set to ON and for which RANGE has not been set to SKIP.

Example 1: File size for 500 points, 50 channels:

$$(2 \times 500 \times 50 + 256 + 64 \times 50) / 1024 = 52.2$$

About 52K bytes will be used (1K bytes=1024 bytes).

Example 2: File size for 32000 points, 4 channels:

$$(2 \times 32000 \times 4 + 256 + 64 \times 4) / 1024 = 250.5$$

About 250K bytes will be used. (1K bytes = 1024 bytes)

(4) The total number of files in an IC memory card cannot exceed 48.

Example:

Three panel setting files }
Four sampled data files }

The IC memory card in which these files are registered will contain $3 + 4 + 1 = 8$ files

↓
Volume information file

7.1.7 Storing Setting Information (SET)

Function

Combining setting information files of ranges and other such parameters with measured data files, up to 48 files can be stored.

Selections

- (1) LOAD : Loads setting information from IC memory card into recorder.
- (2) SAVE : Saves setting information from recorder to IC memory card.
- (3) DEL : Deletes an unwanted file.

[LOAD Example]

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: **MEMORY**, *** F1**, **ENTRY**

MEMORY=SET

↓SET WRITE READ INFO

↓INIT

Key entry: *** F1**, **ENTRY**

SET=LOAD

LOAD SAVE DEL

Key entry: *** Function keys or alphanumeric keys**, **ENTRY**


SET LOAD=

↓FILE1 FILE2 FILE3 FILE4

↓FILE5 FILE6 ----

} File names previously saved are displayed.

Loading



- Load setting information in IC memory card.
- Input file name of file to be loaded.
- Files previously saved can be selected using the function.
- The file name can also be input using the numeric keys.
- Loading begins.
- GP-IB and RS-232C communications cannot be used while loading is in progress.
- When loading ends, the screen returns to data display mode.

[SAVE Example]**[Key Entry, Panel Displays]** The panel displayed when * key is pressed.**[Description]**

Key entry: **MEMORY**, *** F1**, **ENTRY**

MEMORY=SET

↓SET WRITE READ INFO

↓INIT

Key entry: *** F2**, **ENTRY**

SET=SAVE

LOAD SAVE DEL


Key entry: *** Function keys or alphanumeric keys**, **ENTRY**

SET SAVE=

↓FILE1 FILE2 FILE3 FILE4

↓FILE5 FILE6 ----

} File names previously saved are displayed.

Saving 

***** SAVE END *****

- Save setting information to IC memory card.

- Input file name of file to be saved.
- If a previously saved file is to be re-used, it can be selected using the function keys. The file name can also be input using the numeric keys.

- Saving begins.
- An error message will be displayed at this time if the number of files exceeds 48, or there is no IC memory card capacity.

- Saving is completed.

Note: Each setting information file = 20K bytes

[DEL Example]**[Key Entry, Panel Displays]** The panel displayed when * key is pressed.**[Description]**

Key entry: **MEMORY** , *** F1** , **ENTRY**

MEMORY=SET

↓SET WRITE READ INFO

↓INIT

Key entry: *** F3** , **ENTRY**

SET=DELETE

LOAD SAVE DEL

Key entry: *** Function keys or alphanumeric keys** , **ENTRY**

DEL FILE=

↓FILE1 FILE2 FILE3 FILE4

↓FILE5 FILE6 ----

} File names previously saved are displayed.

Key entry: **ENTRY**

*** FILE DELETE ***

- Delete unwanted file from among the setting information files on the IC memory card.
- Use the function keys to select the setting information file to be deleted. The file name can also be input using the numeric keys.
- The deletion is completed.

7.1.8 Measured Data Storage

(1) Data Write (WRITE)

Function Write data to IC memory card.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: **MEMORY**, *** F2**, **ENTRY**

MEMORY=DATA-WRITE

↓SET WRITE READ INFO

↓INIT

- Select write.

Key entry: *** F1**, **ENTRY**

WRITE=TRIGGER

↓TRIG DIRECT STOP CH-SET

↓DEL

- Select method to use for write.

- TRIG {
 - Alarm occurrence
 - Chart end
 - Remote control contact input (/REM option)
 Begins acquiring measured data to IC memory using any of the above as a trigger.
- DIRECT Begins acquiring data to IC memory card as soon as settings completed.
- STOP Used when you wish to abort writing of data to IC memory card while the write is in progress.
- CH-SET Specifies only required channels among those whose measured data is being acquired to the IC memory card.
- DEL Deletes measured data file already present on IC memory card.

In the setting procedures that follow, the information to be entered differs for each menu selection.

[When TRIG is Selected]

Acquisition of measured data to the IC memory card can be started using an alarm occurrence chart end, or remote control contact input as a trigger.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: * Function keys or alphanumeric keys , ENTRY

WRITE FILE=FILE

↓FILE1	FILE2	FILE3	FILE4
↓FILE5	FILE6	----	

} File names previously saved are displayed.

- Input the file name.

Key entry: * F1 , ENTRY

SAMPLE=INTVL

↓INTVL	1min	2min	5min
	10min	----	

- Decide the interval with which data will be sampled to the IC memory card.

INTVL ... Causes data to be sampled at the scan interval.

Key entry: * F2 , ENTRY

MEM.LEN=1K

↓0.5K	1K	2K	4K
	8K	16K	32K

- Acquire 1K (1000) data samples. This sampling designation applies to all channels which have been specified as ON using CH-SET and have not been set for SKIP in RANGE setting.

Key entry: * F2 , ENTRY

PRE TRIG=10

↓0	10	20	30
↓40	50	60	70
↓80	90	100	

- Set a pre-trigger. Enables you to specify what percentage of the total data acquired in the IC memory card will consist of pre-trigger data.

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * F2 , **ENTRY**

TRIG ALARM=ON

OFF ON

- Select whether or not to use an alarm occurrence as a trigger to start sampling of data to the IC memory card.

Key entry: **SHIFT** , I 9 , P 0 , * M 1 , **ENTRY**

(When TRIG ALARM ON)

RELAY=I01

► I**=INT S**=SWITCH

- If ON was selected above, input the relay number of the alarm output which will become the trigger.
- I** Internal alarm output relay
S** Internal switch

Key entry: * F1 , **ENTRY**

TRIG RMT=OFF

OFF ON

- Select whether or not to use a remote control (option) contact input as the trigger to start sampling of data to the IC memory card.

Key entry: * F1 , **ENTRY**

TRIG CHART=OFF

OFF ON

- Select whether or not to use a chart end as a trigger to start sampling of data to the IC memory card.

*** TRG START ***

- Setting is completed and recorder begins waiting for the triggers.
- Pressing **ENTRY** once more returns the recorder to the initial screen.

[DIRECT]

Measured data acquisition to the IC memory card begins as soon as setting is completed.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: **MEMORY**, **F2**, **ENTRY**, *** F2**, **ENTRY**

WRITE=DIRECT

↓TRGR DIRECT STOP CH-SET

↓DEL

Key entry: * **Function keys or alphanumeric keys**, **ENTRY**

WRITE FILE=FILE

↓FILE1 FILE2 FILE3 FILE4

↓FILE5 FILE6

} File names previously saved are displayed.

- Input the file name.

Key entry: * **F1**, **ENTRY**

SAMPLE=INTVL

INTVL 1min 2min 5min

10min ----

INTVL Causes data to be sampled at the scan interval.

- Decide the interval with which data will be sampled to the IC memory card. This sampling specification applies to all channels which have been specified as ON using CH-SET and have not been set for SKIP in RANGE setting.

Key entry: * **F2**, **ENTRY**

MEM.LEN=1K

↓0.5K 1K 2K 4K

8K 16K 32K

- Acquire 1K (1000) data samples.

*** WRITE START ***

- Sampling to the IC memory card begins as soon as the setting is completed.

[When CH SET is Selected]

CH SET is used to select only those required channels from among the measured data for acquisition to the IC memory card.

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: **MEMORY**, **F2**, **ENTRY**, *** F4**, **ENTRY**

WRITE=CH-SET

↓TRGR DIRECT STOP CH-SET

↓DEL

Key entry: *** F1**, **ENTRY**

01:MEMORY=ON

ON OFF ESC

- The initial value is ON for all channels.
- Use the **CH UP** **△**, **CH DOWN** **▽** and **CH-SET** keys to change the channel No. for selection.

Key entry: **ENTRY**

*** SET OK ***

- Select this channel for acquisition of measured data to the IC memory card.

- Pressing the **ENTRY** key once more returns the recorder to the CH-SET starting screen.
- Press ESC (**F3**) and **ENTRY** key to end.

[When DEL is Selected]

Deletes a file already present on the IC memory card.

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: **MEMORY** , **F2** , **ENTRY** , **NEXT** ,
*** F1** , **ENTRY**

WRITE=DELETE

↓TRGR DIRECT STOP CH-SET

↓DEL

Key entry: * **Function keys** , **ENTRY**

DEL FILE=FILE

↓FILE1 FILE2 FILE3 FILE4

↓FILE5

- Select the name of the file to be deleted from the IC memory card.

Key entry: **ENTRY**

***** FILE DELETE *****

- The file has been deleted.


[About Triggering Conditions]

① Pretrigger


Pretriggering is used with sampling in the trigger mode.

Setting pretrigger to 0% effectively disables pretrigger, so that only data measured after the trigger is retained.


When pretrigger is set to a value other than 0% and the triggering condition is detected, data acquired prior to the trigger is retained in an amount determined by the specified pretrigger fraction, data acquired earlier is discarded, and data sampling continues uninterrupted following the trigger.



- If the trigger is detected before enough data has been acquired to fill the pretrigger size allocation, the pretrigger data area becomes the data acquired since the start of sampling, and the post-trigger data becomes the data acquired from trigger detection until the specified data length is reached.



- Trigger detection when measurement interval and sample interval differ :




▼ IC memory card write interval timing

When the IC memory card write interval and measurement interval differ (see figure above), and the trigger occurs in the interval between IC memory card write times (B in figure above), the data written to the IC memory card as the apparent trigger point data is that measured at next IC memory card write time (A in figure above).

② Internal alarm trigger

The occurrence of an alarm condition can be used as the trigger for IC memory card operation.

When this is done, the trigger is applied at the leading edge of the alarm event. If an alarm is already present when sampling is begun and the trigger wait state is entered, it will not act as a trigger.




- If the alarm occurs at time A and the IC memory card operation and trigger wait are started at time X, triggering will not take place. However, if the alarm occurs again at time B, then B will become the triggering point.
- If the IC memory card operation and trigger wait are started at time X, and the alarm occurs at time B, then B will become the triggering point.

③ External Contact (Contact Input via Remote Control /REM)

Triggering occurs when the external contact goes from OFF to ON (edge detection), starting IC memory card data writes.

Triggering will not occur if the contact is already ON when the recorder enters the trigger wait state.




- If the external contact turns ON at time A, and the IC memory card operation and trigger wait are started at time X, triggering will not take place. However, if the contact makes an OFF to ON transition again at time B, then B will become the triggering point.
- If the IC memory card operation and trigger wait are started at time X, and the contact off to on transition occurs at time B, then B will become the triggering point.

[Trigger Detection Timing]


Actual trigger detection is performed with the timing indicated by point © in the figure below. Since for contact detection the recorder retains the contact status at ④, this means that even if the contact goes from off to on at point ③ this will not result in triggering at point ©. Triggering will result in the next interval at ④.

In the case of alarms or chart end, triggering will result at © even if they occur at ③.



[Recorder Displays]

Trigger waiting state




- When different operating states are in force for READ and WRITE, then the indications for memory operation in-progress, trigger wait, and stopped are displayed in sequence.

Example :

If WRITE is in progress with READ waiting for trigger, the M symbol is displayed.

IC memory card in operation



CAUTION

1. Do not remove the IC memory card while data write is in progress.
 - (1) If the IC memory card is removed while a data write operation is in progress, data write will halt, and it may be impossible to retrieve previously recorded data from that file.
 - (2) Such a file should be deleted using DEL in the WRITE menu of the MEMORY settings.
2. The following changes will stop data writing to the IC memory card. However, data already recorded on the IC card can still be retrieved.
 - (1) Measurement channels: changes made to measurement mode (SKIP, VOLT, TC, etc.), measurement range, SCALE settings (SPAN LEFT, SPAN RIGHT, SCALE LEFT, SCALE RIGHT), or DELTA settings (reference channel, or the reference channel's mode or range).
 - (2) Math channels: changes made to MATH mode (ON / OFF), SPAN LEFT, SPAN RIGHT, or calculation formula.

(2) Data Read (READ)

[Specifying Channels at Time of Data Read]

The data written to the IC memory card can be played back using the computation channels 31 through 60.

Note:

- To play back data on a recorder not equipped with the /MATH computation option, you must set to ON the MEM INPUT parameter under "CONTRL" in the SET UP mode.

This is the SET UP MODE "CONTRL" display. (Refer to Section 6.11.3)

MEM INPUT=ON

ON OFF

- During WRITE, channels set to OFF will be processed as though set for SKIP.
- In addition to the above setting, the setting described below must be done using the AUX key.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: AUX , NEXT , NEXT , NEXT ,
* F1 , ENTRY

AUX MODE=31~60

↕CLOCK
SYSTEM
PRINT
TAG

↕MSG
HEADER
ZONE
PART

↕INTVL
ELSE
INTER
MOVAVE

31~60
CONST

- Channels 31 through 60 are set for use by memory.

Setting up to play back on channel 31 data written to the IC memory card from channel 01.

Key entry: * F2 , ENTRY

31:MODE=ON

OFF ON

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * **Function keys or alphanumeric keys** , **ENTRY**

31=M01

↓SQR(ABS(LOG(EXP(
↓TLOG(CLOG(MAX(MIN(
↓AVE(SUM(P-P(SD(
↓.EQ.	.NE.	.GT.	.LT.
↓AND	OR	NOT	XOR
↓)	K	M	G

(Screen for recorder with /MATH option)

- Assign channel 31 to channel 1 data written to IC memory card.

Key entry: * **Alphanumeric keys** , **ENTRY**

31:SPAN L=-2000.0

▶ Scale Span -30000~30000

- Input recording span left value.

Note: On models with /MATH option, include decimal point when entering. On models without /MATH option, do not specify decimal point. The decimal point position is automatically retrieved from the IC Memory Card data.

Ex.) -20.000 : Input as -20000.

Key entry: * **Alphanumeric keys** , **ENTRY**

31:SPAN R=2000.0

▶ Scale Span -30000~30000

- Input recording span right value. A decimal-point position is the same position as for the left span.

Key entry: * **Alphanumeric keys** , **ENTRY**

31:UNIT=

▶ Up to 6 Characters

- Input unit (up to 6 characters).

Key entry: **ENTRY**

*** SET OK ***

31 ON M01

- Setting is complete. Repeat the procedure in the same manner for channels 32 through 60.
- To begin data retrieval continue on next page.

[Beginning Data Retrieval]

This procedure reads back data previously written into an IC memory card (computed data written to the card can also be read back).

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: MEMORY , * F3 , ENTRY

MEMORY=DATA-READ

↓SET WRITE READ INFO

↓INIT

- Select read.

Key entry: F1 , ENTRY

READ=TRIGGER

TRIG DIRECT STOP INFO

- Specify procedure to use for reading.

- Readback from the IC memory card can be triggered by:
- TRIG {
 - Alarm detection
 - Remote control (/REM option) contact input
 - DIRECT Begins reading data from IC memory card as soon as setting is complete.
 - STOP Used to abort an IC memory card data read operation in progress.
 - INFO Obtains display of information on data to be read back from the IC memory card.

In the setting procedures that follow, the information to be entered differs for each menu selection.

[When TRIG is Selected]

Data can be readback from the IC memory card using an alarm occurrence or remote control contact input as a trigger.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: * Function keys or alphanumeric keys , ENTRY

READ FILE=FILE1

↓FILE1 FILE2 FILE3 FILE4
↓FILE5 FILE6

} File names previously saved are displayed.

- Input name of the file to be read.

Key entry: * Numeric keys , ENTRY

START DATA =1

► Input Start Data 1~32000

- Specify the number of the data sample from which to begin reading.

Key entry: * F2 , ENTRY

TRIG ALARM=ON

OFF ON

- Select whether or not to use the occurrence of an alarm as the trigger for readback of data from the IC memory card.

Key entry: SHIFT , I 9 , P 0 , * M 1 , ENTRY

RELAY=I01

► I**=INT S**=SWITCH

- If ON was selected above, input the relay number of the alarm output which will become the trigger.
 { I**Internal alarm output relay
 { S**Internal switch

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * F1 , **ENTRY**

TRIG RMT=OFF

OFF ON

- Select whether or not to use a remote control (option) contact input as the trigger for readback of data from the IC memory card.

Key entry: * F1 , **ENTRY**

TRIG CHART=OFF

OFF ON

- Select whether or not to use a chart end as a trigger to start sampling of data to the IC memory card.

*** TRG START ***

- Setting is completed and recorder begins waiting for the triggers.
- Pressing **ENTRY** once more returns the recorder to the initial screen.

* In the TRIGGER mode, making all trigger OFF results in ERROR.

[DIRECT]

Readback of the data from the IC memory card begins as soon as setting is completed.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: MEMORY, * F2, ENTRY

READ=DIRECT

↓TRIG DIRECT STOP INFO

Key entry: * Function keys or alphanumeric keys, ENTRY

READ FILE=FILE1

↓FILE1 FILE2 FILE3 FILE4 } File names previously saved are displayed.

↓FILE5 FILE6

- Input the name of the file to be read.

Key entry:

START DATA=1

▶ Input Start Data 1~3200

- Specify the number of the data sample from which to begin reading.

*** READ START ***

- Setting is complete, and readback of data from the IC memory card begins.

[Display During Readback]

Display while awaiting trigger.

01 H -123.45mV

02 ddH -123.45mV ▲AUTO 

Display while read in progress.

01 H -123.45mV

02 ddH -123.45mV ▲AUTO **[Display at END of Readback]**

After all data has been read, or if the recorder is waiting for a trigger or not performing a read, the data for M ☐ ☐ channels is assigned the "SKIP" value.

If a SKIP value is used for computation on a computation channel (from 31 through 60), a computation error will result in yielding a value of "+OVER" or "-OVER" (selected when setting MATH ERROR processing in SET UP mode).

CAUTION


- Do not turn OFF the recorder power (including power failures, etc.) while a trigger wait, data read or data write operation is in progress.
Even if power recovers, the trigger wait, data write and data read operations will abort.
- Data readback is done once each measurement interval.

① Alarm Trigger

An alarm condition can be used as a trigger. When this is done, the recorder triggers and begins reading data on the leading edge of the alarm event.

If an alarm is already present when the recorder enters the trigger wait state, it will not act as a trigger.

• Alarm




In the case of alarm triggering, data readback begins from the next measurement interval following the one that detects it (alarm occurs at point A).

② External Contact (Via Remote Control /REM Option) Trigger

Triggering occurs when the external contact goes from OFF to ON (edge detection), starting data readback.

Triggering will not occur if the contact is already ON when the recorder enters the trigger wait state.




- If the external contact turns ON at time A, and the data read operation is initiated at time X, triggering will not take place. However, if the contact makes an OFF to ON transition again at time B, then readback will begin.
- If the data read operation is initiated at time X, and the contact OFF to ON transition occurs at time B, then readback will begin from point B.

③ Trigger Detection Timing

Actual trigger detection is performed with the timing indicated by point ③ in the figure below. Since for contact detection the recorder retains the contact status at ①, this means that even if the contact goes from off to on at point ② this will not result in triggering at point ③. Triggering will result in the next interval at ④.

In the case of alarms or chart end, triggering will result at ③ even if they occur at ②.



(3) Checking Setting and Measurement Information (INFO)

Used to display information about what kind of data is stored on an IC memory card.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: **MEMORY**, *** F3**, **ENTRY**

MEMORY=DATA-READ

↓SET WRITE READ INFO

↓INIT

- Select read.

Key entry: *** F4**, **ENTRY**

READ=INFO

TRGR DIRECT STOP INFO

- Select information read.

Key entry: **Function keys**, **ENTRY**

INFO FILE=

↓FILE1 FILE2 FILE3 FILE4 } File names previously saved are displayed.

↓FILE5 FILE6

- Use the function keys to select the file for which you want information.

Key entry: **ENTRY**

▶ SAMPLED BY: HR

▶ Sampled Machine

- Since the IC memory card may be used with other YOKOGAWA products (LR, DMM etc.), this display shows that the data about to be read is data from this device.

Key entry: **ENTRY**

▶ 88/01/01 00:59

▶ Trigger Time

- Display date and time that the data was written to the IC memory card.

(For data from other products which does not contain data and time information, the display shows "00/00/00 00:00")

The following shows for which channels data was written to the IC memory card.

{ Channel written = ■
 { Channel not written = □

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

<p>Key entry: ENTRY</p> <p>▶ 01~10: ■ ■ ■ ■ □ ■ □ □ □ □</p> <p>▶ MEM ON=■ MEM OFF=□</p>	<ul style="list-style-type: none"> Channels 1 through 10
<p>Key entry: ENTRY</p> <p>▶ 11~20: ■ ■ ■ ■ □ ■ □ □ □ □</p> <p>▶ MEM ON=■ MEM OFF=□</p>	<ul style="list-style-type: none"> Channels 11 through 20
<p>Key entry: ENTRY</p> <p>▶ 21~30: □ □ □ □ □ □ □ □ □ □</p> <p>▶ MEM ON=■ MEM OFF=□</p>	<ul style="list-style-type: none"> Channels 21 through 30 (everything □)
<p>Key entry: ENTRY</p> <p>▶ 31~40: ■ ■ ■ ■ □ ■ □ □ □ □</p> <p>▶ MEM ON=■ MEM OFF=□</p>	<ul style="list-style-type: none"> Channels 31 through 40
<p>Key entry: ENTRY</p> <p>▶ 41~50: ■ ■ ■ ■ □ ■ □ □ □ □</p> <p>▶ MEM ON=■ MEM OFF=□</p>	<ul style="list-style-type: none"> Channels 41 through 50
<p>Key entry: ENTRY</p> <p>▶ 51~60: ■ ■ ■ ■ □ ■ □ □ □ □</p> <p>▶ MEM ON=■ MEM OFF=□</p>	<ul style="list-style-type: none"> Channels 51 through 60

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: **ENTRY**

▶ DATA LEN: 32000

▶ Data Length

- Display number of data samples



Key entry: **ENTRY**

▶ SAMPLE=2sec

▶ Sample Rate

- Display interval at which data sampling was performed.



Key entry: **ENTRY**

▶ TRIG POINT=20000

▶ Trigger Point

- Displays number of data sample at which trigger occurred.
(Display will read "1" if pretrigger = 0% or sampling is done in DIRECT mode.)



Key entry: **ENTRY**

INFO END

- Information display completed.

(4) Displaying Capacity Remaining on IC Memory Card

Displays the capacity remaining on the IC memory card.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. **[Description]**

Key entry: MEMORY, * F4, ENTRY

MEMORY=INFO

↓SET WRITE READ INFO

↓INIT

- Select IC memory card information (INFO).



Key entry: ENTRY

▶ VOLUME=NEW-HR

▶ Push Entry

- Display IC memory card volume name.



Key entry: ENTRY

▶ MEMORY=60K BYTE

▶ Push Entry

- Display IC memory card memory remaining.




Key entry: ENTRY

INFO END

8. CONTACT OUTPUTS AND INPUTS

HR2300 Rear Panel Option Arrangement



※ Note: Contact I/O connector signals

(Connector for recorder fail, chart end, common alarm output, internal alarm output relay (AK-02), and remote control terminals (/REM))


Figure 8.1 Rear Panel Option Arrangement

8.1 Remote Control Function (Option /REM) Specifications


This option enables the recorder functions to be controlled externally by contact inputs.

- Controlled Functions** : 1. Message print command (1 to 5 messages)
2. Recording start/stop
3. Chart speed and logging interval changes
4. Manual print command
5. Digital print command (for use during trend mode)
6. IC memory card data write and read commands
- Input Signals** : Dry contact or open-collector (TTL or transistor)
- Input Conditions** : ON voltage (0.5V maximum) (30mA DC)
Leakage current in OFF state (0.25mA maximum)
Signal duration (one second minimum)
- Input Type** : Photocoupler isolation (one side common)
Internal isolated power source (5V \pm 5%)
- Dielectric Strength** : Between input and ground terminals
1000 V (50 or 60 Hz) for one minute
- Power Consumption** : Included in the standard value for the recorder.

Wire and use the accessory connector.



- RE 1 : Chart speed, logging interval change
- RE 2 : Recording start/stop
- RE 3 : Digital print (in trend mode)
- RE 4 : Manual print
- RE 5 : IC memory card read
- RE 6 : IC memory card write
- RE 7 : Message print 1
- RE 8 : Message print 2
- RE 9 : Message print 3
- RE 10 : Message print 4
- RE 11 : Message print 5
- COM : Common



Note : To print Message 1, connect wires to pins 15 and 11 (or 29).




Figure 8.2 Remote Connector

8.2 Internal Alarm Output Relays (Option /AK-02)

(Refault Realarm Output Relay)


Number of Output Contacts: 2 points

Output Type : Relay transfer contact + single-point common
Energize / de-energize operation can be switched (set in energized when panel mount shipment)

Output Capacity : 24V DC, 0.5A Life 300,000 cycles
(resistive load with arc suppressor)

Dielectric Strength : 1000V (50 or 60Hz) for one minute between output and ground terminals

Power Consumption: Included in recorder standard specification.



Wiring required to accessory connector.

5 I01

4 I02

3 Common alarm output relay

Two of the internal alarm output relay points output via pins number 6 and 7, and 23 through 26 of the left-hand remote control connector as seen from the rear. The common alarm output relay uses pins 4, 5 and 22.





Figure 8.3 Internal Alarm Output Relay (AK-02) Connector

8.3 Standard Contact Output Function


The HR1300 is equipped as standard with functions for contact output of "Recorder Fail" and "Chart End". The type and capacity of the output contacts is the same as for the alarm contacts (there is no switching between energized and de-energized operation).



The same connector as for the remote control and AK-02 is used. The connector wiring is as follows.

- 1 Recorder FAIL output (de-energize on alarm).
- 2 Chart end output (energize on alarm).





9. MAINTENANCE (FUSE REPLACEMENT)




Figure 9.1 Fuse Replacement

We recommend that you replace the fuses every two years for preventive maintenance.

- (1) Turn OFF the power switch.
- (2) Pull out the fuse box at the side of the rear panel power connector and replace the fuses. The fuses used are 1.25A time-lag types. (Part number: A9197KF)

10. ACCESSORY, MODEL NAMES AND PART NUMBERS

Accessories available for the HR1300 include the IC memory cards, external alarm output relays, push-in input terminal blocks, screw input terminal blocks, DC current input shunt resistors, and rack mounting adapter.

3789 03	IC Memory Card, 64K bytes (for setting, measured and computed data)
3789 04	IC Memory Card, 256K bytes (for setting, measured and computed data)
3789 05	IC Memory Card, 512K bytes (for setting, measured and computed data)
3798 11	3750 Rack Mounting Adapter (JIS)
3798 13	3750 Rack Mounting Adapter (ANSI)
3798 01	Clamped Input Terminal Blocks
3798 02	Screw Input Terminal Blocks
4389 20	250 Ω \pm 0.1% Shunt Resistor for Clamped Input Terminal Blocks
4389 21	100 Ω \pm 0.1% Shunt Resistor for Clamped Input Terminal Blocks
4389 22	10 Ω \pm 0.1% Shunt Resistor for Clamped Input Terminal Blocks
4159 20	250 Ω \pm 0.1% Shunt Resistor for Screw Input Terminal Blocks
4159 21	100 Ω \pm 0.1% Shunt Resistor for Screw Input Terminal Blocks
4159 22	10 Ω \pm 0.1% Shunt Resistor for Screw Input Terminal Blocks

B9627AZ 10-color Ribbon

B9855AY Z-Fold Recording Chart (20m) 10mm Style

11. RECORDER SPECIFICATIONS

MEASUREMENTS

Number of Inputs: Up to 10 or 20 points.

Input Types, Range, Accuracy and Resolution:

Input Type	Range	Measurement (Digital display & printout)		Recording (Analog trend)			
		Accuracy	Resolution	Accuracy	Resolution		
DC V	20 mV	$\pm (0.05\% \text{ of rdg} + 5 \text{ digits})$	1 μ V	$\pm 0.2\%$ of span (not including measure- ment accuracy)	$\pm 0.04\%$ of span		
	60 mV	$\pm (0.05\% \text{ of rdg} + 2 \text{ digits})$	10 μ V				
200 mV	$\pm (0.05\% \text{ of rdg} + 2 \text{ digits})$	10 μ V					
2 V	$\pm (0.05\% \text{ of rdg} + 2 \text{ digits})$	100 μ V					
6 V	$\pm (0.05\% \text{ of rdg} + 2 \text{ digits})$	1mV					
20 V	$\pm (0.05\% \text{ of rdg} + 2 \text{ digits})$	1mV					
50 V	$\pm (0.05\% \text{ of rdg} + 2 \text{ digits})$	10mV					
TC	R	$\pm (0.05\% \text{ of rdg} + 1^{\circ}\text{C})$	0.1 $^{\circ}\text{C}$				
	S	R, S: 0 to 100 $^{\circ}\text{C} \pm 3.7^{\circ}\text{C}$ 100 to 300 $^{\circ}\text{C} \pm 1.5^{\circ}\text{C}$ B: 400 to 600 $^{\circ}\text{C} \pm 2^{\circ}\text{C}$					
	B		0.1 $^{\circ}\text{C}$				
	K	$\pm (0.05\% \text{ of rdg} + 0.7^{\circ}\text{C})$ -200 to -100 $^{\circ}\text{C}$ $\pm (0.05\% \text{ of rdg} + 1^{\circ}\text{C})$					
	E	$\pm (0.05\% \text{ of rdg} + 0.5^{\circ}\text{C})$ J, L: -200 to -100 $^{\circ}\text{C}$ $\pm (0.05\% \text{ of rdg} + 0.7^{\circ}\text{C})$					
	J						
	T						
	*1 L *1 U		0.1K				
	Kp vs Au7Fe	$\pm (0.05\% \text{ of rdg} + 0.7\text{K})$					
	*2 N	$\pm (0.1\% \text{ of rdg} + 0.7^{\circ}\text{C})$	0.1 $^{\circ}\text{C}$				
*2 W	$\pm (0.1\% \text{ of rdg} + 1^{\circ}\text{C})$						
RTD	Pt100 (1mA, 2mA) JPt100 (1mA, 2mA) Pt50 (2mA)	$\pm (0.05\% \text{ of rdg} + 0.3^{\circ}\text{C})$	0.1 $^{\circ}\text{C}$				
	Pt50 (2mA)	$\pm (0.05\% \text{ of rdg} + 0.3^{\circ}\text{C})$					
	*3 Ni 100 (1mA) *4 Ni 120 (1mA)	$\pm (0.05\% \text{ of rdg} + 0.3^{\circ}\text{C})$	0.1 $^{\circ}\text{C}$				
	J263*B	$\pm (0.05\% \text{ of rdg} + 0.3\text{K})$	0.1K				
	Cu10 Ω GE, L&N, WEED, BAILEY	$\pm (0.2\% \text{ of rdg} + 0.7^{\circ}\text{C})$	0.1 $^{\circ}\text{C}$				
	High-sensitivity model Pt100 (1 mA) Pt100 (2 mA) JPt100 (1 mA) JPt100 (2 mA)	$\pm (0.05\% \text{ of rdg} + 0.3^{\circ}\text{C})$	0.01 $^{\circ}\text{C}$				
Contact Status	Input signal : contact status or DC V						

- *1 :
L ; Fe-CuNi
U ; Cu-CuNi
*2 :
N ; Nicrosil-Nisil
W ; W-5%Re - W 26%Re
*3 : SAMA / DIN
*4 : McGRAW EDISON
*5 :
Pt50 ; JIS C1604-1981
JIS C1606-1986
Pt100 ; JIS 1604-1989
JIS 1606-1989
DIN IEC751,
IEC751
JPt100 ; JIS C1604-1989
JIS C1606-1989

Reference Junction Compensation Error:

$\pm 1^{\circ}\text{C}$ (R, S, B, W), $\pm 0.5^{\circ}\text{C}$ (K, J, E, T, N, L, U, Kp vs Au7Fe).

Scan Cycle Time: 2 to 60s selectable (2, 3, 4, 5, 6, 10, 12, 15, 20, 30, 60s).

Scanning Rate: Max. 20 points / 2 seconds.

A-D Integration Time: 20mS (50Hz), 16.7 mS (60Hz), and 100mS (50 / 60Hz) are selectable via an internal switch.

Input Impedance: More than $10\text{M}\Omega$ on 2V or lower ranges and TC, approx. $1\text{M}\Omega$ on 6V or higher ranges.

Input Bias Current: Less than 10nA.

TC Burnout Protection: $2\text{k}\Omega$ or less (normal), $100\text{k}\Omega$ or more (open), current approx. $6\mu\text{A}$, detection pulse width approx. 2mS (ON or OFF selectable for each channel).

Temperature Spread on Terminals:

Within 0.3°C among input terminals when temperature is balanced.

Allowable Source Resistance: Less than $1\text{k}\Omega$ (DC V & TC).

Temperature Coefficient:

Zero drift ... 0.01% of range / $^{\circ}\text{C}$,

Full Span ... 0.01% of range / $^{\circ}\text{C}$.

Maximum Allowable Input Voltage: 60V DC.

Maximum Common Mode Voltage between terminal and case: 250V AC rms.

Maximum differential noise between channels: 150V AC rms (50 / 60Hz).

Common Mode Rejection: More than 120dB (50 or 60Hz $\pm 0.1\%$).

Normal Mode Rejection: More than 40dB (50 or 60 Hz $\pm 0.1\%$).

PRINTOUT

Printing Technique: Raster scan using a wire-dot printer and a 10-color ribbon.

Effective Recording Span: 150mm (analog data).

Chart: Z-fold chart (230mm \times 20m) with calibrated width of 150mm.

Recording Colors: Analog data (TREND

mode) ... 10 colors (purple, red, green, blue, brown, black, navy blue, yellowish green, purplish red, orange), color can be specified for every channel, digital data (TREND mode) ... channel number, measured data, date & time, chart speed (black), alarm (ON mark ; red, OFF mark ; blue), LOG & LIST modes ... all data (purple).

Recording Accuracy: Measurement accuracy $+(\pm 0.2\%$ of effective recording span).

Printout Format: Analog trend / analog trend + digital / logging.

The following recording is available in trend mode, zone recording ... recording width and recording position (0 and 100% position) settable in 1mm steps, partially expand scale printout ... can be specified for every point (one break point).

Recording can also be turned ON / OFF every channel for the following items (panel setting), analog recording, digital printing, interpolation and moving average recording. Recording common to all channels for the following items (panel setting) can be turned ON / OFF; alarm printing, scale value printing, scale value tick, and vertical or horizontal printing selectable in the logging mode.

Chart Speeds: 1 to 1,500mm / h.

Change of Chart Speed: Chart speed or logging interval is changed by remote control signals (optional) or alarm occurrence.

Print Cycle Time (Interval):

Analog recording interval in the trend mode FIX mode ... recording interval is same as measuring interval.

AUTO mode ... recording interval is determined in accordance with the chart speed. Digital recording interval in the trend mode MULTIPLE mode ... selectable for each channel from any of three values (1min to 24h).

SINGLE mode ... chart speed and the number of recording lines automatically determine digital interval.

Interval in the logging mode:

MULTIPLE mode ... chosen and recorded from one of three types of interval every channel (1min to 24h).

SINGLE mode ... recorded at a determined interval.

Chart Drive: Pulse motor drive.

Chart Speed Accuracy: $\pm 0.1\%$ (for recording longer than 1m).

Start Time: Programmable for measurement (scan) and printing start time or T L interval.

Printout Mode:**1. NORMAL:**

Printing starts when START / STOP switch turned ON and stops when switch is turned OFF.

2. PRINT ON ALARM (Either one of the following is settable):

TRIGGER mode ... Printing starts at set alarm ON^{*1}, and stops at START/STOP switch OFF (set on shipment at the factory).

LEVEL mode ... Printing starts at set alarm ON^{*1}, and stops at alarm OFF.

3. CHART SP / INTVL CHANGE ON ALARM:

Chart speed/interval changes at set alarm ON^{*1}, and restored at alarm OFF.

*1: All of the OR alarms or the set alarm.

Engineering Unit Printout: Engineering unit (up to 6 alphanumeric) can be defined and printed out.

Tag Number Printout: Tag number can be printed out in place of channel number (up to 7 alphanumeric).

Alarm Printout: Channel number, alarm type, and the time of alarm ON/OFF are printed.

Scale Markings Printout: Scale values (0/100%, 0/50/100%, or 20% steps) can be printed out.

Program List Printout: Contents of entire setting memory can be listed on the chart.

Manual Printout: Time and measured data for all channels can be printed out for a single line by a push of MANUAL PRINT key, input signal or alarm.

Message Printing: Printing contents ... message (max. 16 characters) and day and time, external contact ... 5 types of messages can be printed out, input signal ... volt-free contact, signal duration of 2 or more, alarm ... 5 types of message (max. 16 characters) can be printed out. Time interval message (max. 16 characters), panel key message (max. 32 characters) is printed out.

Header Printing: Header information of 60 characters × 5 lines is printed by depressing panel key.

Relation of Chart Speed and Printing

Chart Speed (mm/h)	CH No./TAG No.	Date, Hr., Chart-Speed, Measured value	Alarm, Scale Value, Message (title)
1 to 9	○	×	○
10 to 500	○	○	○
501 to 1500	×	×	×

Printing Intervals of Digital Data (Analog recording & digital printout)

Chart Speed (mm/h)	Printing Intervals of Digital Data	
	1 line	2 lines
10 to 24	12 h	6 h
25 to 49	4 h	2 h
50 to 99	2 h	1 h
100 to 500	1 h	30 min

(Interval=Auto)

DISPLAY AND CONTROLS

Type of Display: Vacuum fluorescent large-scaled display (5×7 dot matrix, blue), 2 lines (upper display ... 20 characters, larger size, lower display ... 28 characters, smaller size).

Data Display: Measured data (channel number or TAG, alarm status, measured value, engineering unit), bargraph, clock, alarm status, relay status, programming data, chart end, battery status, and recording format (TREND/LOGGING).

Control Section: Recording keys ... recording start/stop key, control keys for messages and manual printing. Setting keys ... keys for range and alarm setting (function keys, numerical keys) and display changing keys, key lock function ... any keys can be locked/unlocked except for those related to DISPLAY.

Number of Group Programmings: Up to 6 groups, programmable for range, alarm, printing format, tag number and MATH channel (C LOG).

CALCULATION (STANDARD)**Scaling:**

Range ... DC V/TC/RTD

Input range ... each range within the measuring range


Scaling range ... -20000 to +20000

Decimal point ... freely settable.

Difference Calculation (ΔT): Between any channels (within the same range).**Moving Average:** For every 8 scans (ON/OFF is selectable for every channel).**MEMORY CARD****Memory Data:** Setting data, measured data, communication input data and programmed parameter can be stored on a memory card (optional).**Sample Mode and Rate (Common Setting to All Channels):**

In writing: Free mode ... sampling start by manual, sampling interval ... measurement interval or 1/2/5/10min., Trigger mode ... sampling start by trigger condition, sampling interval ... measurement interval or 1/2/5/10min.

In reading: Free mode, Trigger mode ... synchronized with measurement interval.

Memory Capacity: 512, 256 or 64K bytes.**Data Length (Common Setting to All Channels):** 500/1,000/2,000/4,000/8,000/16,000/32,000 data/ch, data length ... 2 bytes/data.**Trigger Conditions:** In Writing ... chart end detection alarm or external contact input (optional), In Reading ... alarm, external contact.**Pre-Trigger:** 0 to 100%, in 10% steps.**Output:** Outpus for communication and recording are possible.**Battery Backup:** Lithium battery, battery life ... about 2 years (256K, 512K bytes), about 4 years (64K bytes).**ALARMS****Number of Alarm Set Levels:** Up to 6 levels /channel.**Alarm Types:** High (H), low (L), high-rate of change (RH), low-rate of change (RL), delta high (ΔH), and delta low (ΔL).**Alarm Programming:** All alarms are programmable via front-panel keys. * high-rate of change (time interval) : Measurement cycle \times (1 to 15).**Display:** The flashing display can be obtained for 20 point alarm status (ch. 1 to 20) + one common point for computing channels (ch. 31 to 60).**Recording:**

Trend mode: CH. No., alarm types, and ON/OFF times in the right margin.

Logging mode: CH. No. and alarm types at the head of measured data.

Alarm Outputs (Optional):

2 points (internal).

AND or OR output as well as REFLASH output can be specified. REFLASH alarm output (500ms) using internal alarm relay contact.

Alarm Acknowledgement: Pressing the ALARM ACK key stops the alarm display flashing and resets the dedicated common relay output.**Alarm Reset:** Hold type relay output by pressing the ALARM RESET key.**CONSTRUCTION****Dimensions:** Approx. 338 (W) \times 221 (H) \times 341.5 (D) mm, (12-3/4" \times 8-11/16" \times 13-3/8").

(clamped input terminal)

Approx. 338 (W) \times 221 (H) \times 360 (D) mm, (12-3/4" \times 8-11/16" \times 14-1/4").

(screw input terminal)

Weight: Approx. 9.7kg (21.4 lbs).**POWER REQUIREMENTS****Power Supply:** 90 to 250V AC (wide voltage range power supply), 50 and 60Hz (must be specified).**Power Consumption:** Approx. 80VA.

NORMAL OPERATING CONDITIONS**Ambient Temperature and****Humidity Range:**

5 to 40°C (41 to 104°F), 20 to 80% R.H.

Input Source Resistance:

Less than 2k Ω (DC V & TC inputs),
less than 10 Ω /wire (Pt100 Ω),
less than 5 Ω /wire (Pt50 Ω),
less than 1 Ω /wire (Cu10 Ω).

GENERAL SPECIFICATIONS

Insulation Resistance: More than 20M Ω at 500V DC between terminals and case.

Dielectric Strength: Between power terminals and ground; 1500V AC (50 / 60Hz) for one minute.

Between contact output terminals and ground; 1000V AC (50/60Hz) for one minute.

Between measurement terminals and ground; 1000V AC (50/60Hz) for one minute.

Between measurement terminals; 1000V AC (50/60Hz) for one minute.

Battery-Backup Memory: Lithium battery, maintains all setting and measured data for about 10 years (23°C \pm 3°C, st'd model).

FAIL Alarm: FAIL lamp lights up when the recorder is in fail condition (FAIL output signal changes to non-inductive).

Chart End Detection: When the chart reaches near its end, "CHART" appears on the display. When recording is automatically stopped, the recorder goes into the monitoring status, and the CHART END output relay is energized (transfer contact).

Clock: With calendar function.

Key Lock Selector: Effective only for specified keys.

Input Terminals: Clamped input terminal block (standard); screw input terminal block (/SIT) (optional). The input terminal block can be removed from the mainframe for easier wiring.

OPTIONAL FEATURES**GP-IB Interface (/GP-IB):**

Conforms to IEEE St'd 488-1978. Talker

Functions: measured value I/O (ASCII and binary, input is ASCII only), Set point I/O

Listener Functions: Setting and controlling available other than for the following: Power ON / OFF, Key lock ON, CHART FEED, SET UP contents, and setting some of the memory functions.

RS-232C Interface (/RS232C):

Conforms to EIA RS-232C.

Mode: Measured value I/O (ASCII and binary, input is ASCII only), set point I/O (ASCII), memory data I/O (ASCII and binary), Setting and controlling available other than for the following: POWER ON / OFF, Key lock ON / OFF, CHART FEED, SET-UP contents, and setting some of the memory functions.

Computation (/MATH):

Types: +, -, \times , \div , SQR (square root), ABS (absolute, value), LOG (common logarithm), EXP (exponential), Maximum, Minimum, Averages, Totals, Max. - Min., Standard deviation, Logic (AND, OR, NOT, XOR).

C LOG ... Computational processing in a group measured at the same time (total, max., min., average, standard deviation, and max-min).

T LOG ... Time series computational processing (max. 24 hours) for a channel (total, max., min., average, and max-min).

Number of channels ... Up to 30 channels, Trend and digital (logging) recording available, analog input of digital input through communications interfaces (/GP-IB or /RS232C) available.

Remote Control (/REM):

Through the contact input, start/stop, chart speed / interval change, manual printout, message recording (5 types), digital recording in the trend mode, writing on the memory card, and loading trigger available.

Input signal: TTL-level, open collector, and contact status.

Internal Alarm Output (/AK-□□):

2 points (internal alarm), contact rating: 24V DC 0.5A

12. PRINTOUT ADJUSTMENT

Set the DIP switch at the rear of the chart cassette to No. 1. Hold it down UPPER DISPLAY and turn ON the power. The SET UP mode is set and the initial panel lifts up.

[Key Entry, Panel Displays] The panel displayed when * key is pressed. [Description]

Key entry: * F1 , ENTRY

SET UP MODE=PRN-ADJ

↓P-ADJ RECORD INTVL END ← LOWER DISPLAY

↓CNTRL KEY COMM BURN
↓GROUP LOGIC RJC COLOR
↓TEMP

Key entry: * Numeric keys , ENTRY

HYS = 0

▶ HYS = -100~100

Key entry: * Numeric keys , ENTRY

ZERO = 267

▶ ZERO = 0~4000

- When ENTRY key is pressed, the printer begins printing out data.
- Change the numeric value to print out data on one vertical line (set at the factory before shipment).
- Can set a minimum printout position.
- ※ Use numeric keys for data entry.
- ※ If the too much value is set, It's not good for carriage.

[Key Entry, Panel Displays] The panel displayed when * key is pressed.

[Description]

Key entry: * numeric keys , ENTRY

FULL = 1485

▶ FULL = 0~4000

- Can set a minimum printout position.
- ※ Use numeric keys for data entry.

Key entry: F1 , ENTRY


PRINT ESC = YES

YES NO

- Press F1 and ENTRY keys concurrently to cancel the printout correction mode.


*** PRINT SET ***

- Press ENTRY key again to return to SET UP mode.



13. SCHEMATIC DIAGRAMS AND PARTS LIST.


Par.	Description	Ass'y No.	Fig. No.	Page
1	Model 3750 (HR1300) Hybrid Recorder Overall Wiring	_____	13-1	13-2




Customer Maintenance Parts List

Model 3750
Hybrid Recorder
(Desk Top Type)


HR1300







<u>Item</u>	<u>Part No.</u>	<u>Qty</u>	<u>Description</u>
1	B9855JA	1	Chat Cassette Assembly } (select either one)
	B9855NT	1	
2	B9619AL	1	Nameplate (for B9855JA: Japanese)
	B9619AN	1	Nameplate (for B9855NT: English)
3	B9619JD	1	Belt
4	—	1	Pulley
5	Y9303SJ	2	Setscrew
6	B9855KG	1	Collar Assembly
7	B9627AG	1	Nameplate
8	B9855BT	1	Nameplate
9	—	1	Case Assembly
10	Y9304LS	4	B. H. Screw M3 × 4
11	Y9405LB	1	B. H. Screw M4 × 5
12	Y9401WL	1	Washer (with toothed lockwasher)


View From A




View From B




Item	Part No.	Qty	Description
1	B9855EA	1	Cover Assembly
	B9855EG	1	Cover Assembly
			(select either one)
2	B9855EE	1	Nameplate (for B9855EA: Japanese)
	B9855EF	1	Nameplate (for B9855EG: English)
3	—	2	Plate
4	Y9405LS	3	B. H. Screw M4 × 5
5	B9855DW	1	Rod
6	—	1	Knob
7	A9055ZB	4	Block
8	B9850KS	4	Bumper
9	Y9414LS	4	B. H. Screw M4 × 14
10	B9627EM	1	Motor (for chart drive)
11	Y9306TY	2	Taptight Screw M3 × 6
12	B9585HY	1	Gear
13	Y9304SJ	1	Setscrew
14	B9585PZ	1	Spacer
15	B9585HR	1	Gear
16	Y9200ET	1	E-Ring
17	A9021KN	1	Spring
18	B9627LG	1	Motor Assembly (for carriage drive)
19	B9590DS	2	Screw
20	—	1	Bracket
21	Y9405LS	2	B. H. Screw M4 × 5
22	—	1	Carriage Assembly
23	Y9304LS	1	B. H. Screw M3 × 4
24	B9627QT	1	Bumper
25	Y9405LS	1	B. H. Screw M4 × 5
26	B9855LF	1	Sensor Assembly
27	Y9304LS	1	B. H. Screw M3 × 4
28	B9855LK	1	Sensor Assembly
29	Y9304LS	1	B. H. Screw M3 × 4
30	B9627DU	1	Pulley Assembly
31	Y9312LS	1	B. H. Screw M3 × 12
32	Y9401CB	1	Nut
33	Y9405LS	5	B. H. Screw M4 × 5
34	Y9304LS	1	B. H. Screw M3 × 4
35	B9855BT	1	Name plate



<u>Item</u>	<u>Part No.</u>	<u>Qty</u>	<u>Description</u>
1	B9855DC	1	Key Sheet
2	B9627YZ	1	Keyboard
3	B9855DD	1	Key Switch
4	B9627PD	1	Tape (length: 500 mm)
5	—	1	Bezel
6	B9855DS	1	IC Memory Card Assembly
7	—	1	Bracket
8	Y9308TY	2	Taptight Screw M3 × 8
9	B9627TE	1	Plate
10	B9855DQ	1	Plate
11	B9628SW	1	V. F. D Module Assembly
12	B9855DP	1	Insulator Sheet
13	—	1	Bracket
14	Y9308TY	2	Taptight Screw M3 × 8
15	Y9306TY	2	Taptight Screw M3 × 6
16	—	1	V. F. D Cover
17	Y9304LS	1	B. H. Screw M3 × 4
18	Y9204KS	1	B. H. Screw M2.3 × 4




Option



Model 3750□□-□□---/DC

View From A



Item	Part No.	Qty	Description
1	B9628XC	1	DI/DO Card Assembly
	B9628QK	1	DI/DO Card Assembly*1
	B9628QL	1	DI/DO Card Assembly*2
	B9628QM	1	DI/DO Card Assembly*3
2	B9628NH	1	GP-IB Card Assembly*4
	B9628NJ	1	RS-232C Card Assembly*5
3	B9628WL	1	ROM Assembly (U4)*4
	B9628WM	1	ROM Assembly (U6)*5
4	B9628XN	1	Scanner Card Assembly*6
5	B9628XN	1	Scanner Card Assembly*7
	B9628SX	1	/AC2 Assembly*8
	B9628SY	1	/AC6 Assembly*9
6	B9628XS	1	A/D Card Assembly
7	B9628XG	1	Printer Board Assembly
8	B9573TZ	1	Fuse (500 mA)
9	B9856WA	1	ROM Assembly
	B9856WC	1	ROM Assembly*10
10	B9856WB	1	ROM Assembly
	B9856WD	1	ROM Assembly*10
11	B9628XF	1	CPU Board Assembly*11
	B9628LA	1	CPU Board Assembly*12
12	Y9330LS	4	B. H. Screw M3 × 30
13	—	1	Bracket
14	Y9304LS	4	B. H. Screw M3 × 4
15	Y9405LS	3	B. H. Screw M4 × 5
16	B9856XA	1	Power Assembly (st'd)
	B9856QA	1	Power Assembly*13
17	B9586JJ	1	Fuse (3.15 A)
18	—	1	Heat Sink
19	Y9306LB	4	B. H. Screw M3 × 6
20	Y9304LS	4	B. H. Screw M3 × 4
21	B9588ZB	1	Battery Assembly
22	Y9902YA	1	Spacer
23	Y9310LS	1	B. H. Screw M3 × 10
24	—	1	Clamp
25	—	1	Cover
26	Y9304LS	4	B. H. Screw M3 × 4
27	—	1	Cover*13
28	B9628QJ	1	DC Power Board Assembly*13
29	Y9304LS	4	B. H. Screw M3 × 4
30	Y9310LS	1	B. H. Screw M3 × 10
31	B9855BT	1	Nameplate
32	A9235SP	1	Switch (st'd)
	A9238SP	1	Switch*13
33	—	1	Bracket
34	Y9304LS	3	B. H. Screw M3 × 4


Note 1

Model	Suffix Code (options)
3750 □□ - □□	/REM
	.../AK-12
	/REM.../AK-12
	/GP-1B
	/RS-232C
	.../AC-2
	.../AC-6
	.../AC□.../ULN
	/ULN
	.../MATH.../ULN
	.../DC

Note 2

*6: 10 points /2s
(high breakdown voltage
Solid state relay)

*7: 20 points /2s
(high breakdown voltage
Solid state relay)



Item	Part No.	Qty	Description
1	B9627YA	1	Terminal Assembly*1
2	B9627YH	30	Screw
3	B9627YA	1	Terminal Assembly*2
4	B9627YH	30	Screw
5	Y9308LS	4	B. H. Screw M3 × 8
6	—	1	Cover
7	B9855BB	1	Nameplate
8	Y9304LS	2	B. H. Screw M3 × 4
9	B9627RN	1	Nameplate
10	Y9304LS	2	B. H. Screw M3 × 4*3
11	—	1	Fuse Holder
12	A9197KF	1	Fuse (1.25 A, timelag)
(13)	A9197KF	1	Fuse (1.25 A, timelag) (accessory)
14	B9627RM	1	Nameplate
15	A9195KF	1	Fuse Carrier
16	A9105KF	1	Fuse (10 A) } *4
17	B9855BZ	1	Nameplate
18	Y9304LS	2	B. H. Screw M3 × 4
19	Y9301WL	2	Washer (with toothed lockwasher) } *5 *6
20	B9627RR	1	Nameplate*5
	B9627RS	1	Nameplate*6
21	B9855BJ	1	Nameplate
22	B9627PA	1	Terminal Assembly
23	B9655FX	30	B. H. Screw M4 × 6 (±) } *1 *7
24	B9578WC	1	R. J. C. Board Assembly
25	—	1	Cover
26	B9627PA	1	Terminal Assembly
27	E9655FX	30	B. H. Screw M4 × 6 (±) } *2 *7
28	B9578WC	1	R. J. C. Board Assembly
29	—	1	Cover
30	B9627ZC	1	Terminal Assembly*2 *8
	B9627ZD	1	Terminal Assembly*2 *9
31	Y9308LS	4	B. H. Screw M3 × 8
32	—	1	Cover
33	B9855BQ	1	Nameplate*7
34	B9627ZA	1	Nameplate*2 *8 } (select either one)
	B9627ZB	1	Nameplate*2 *9
35	Y9304LS	2	B. H. Screw M3 × 4

(select)

Note 1


Model	Suffix Code (options)		
3750 □□	- □□	/REM	.../AK-02
			.../DC
		/GP-IB	
		/RS-232C	
		.../SIT	
		.../AC2	
		.../AC6	
			*3
			*4
			*5
			*6
			*7
			*8
			*9

Note 2

*1: 10 points /2s
(high breakdown voltage
solid state relay)

*2: 20 points /2s
(high breakdown voltage
solid state relay)

Standard Accessories



Item	Part No.	Qty	Description
1	B9627AZ	1	Ribbon Cassette
2	B9197KF	1	Fuse (1.25 A timelag)*1
3	—	1	Instruction Manual
4	—	1	Z-Fold Chart*2
5	B9026KC	1	Connector (36-pin connector)
6	A9009WD	1	Power Supply Cord (other than below)
7	A9008WD	1	Power Supply Cord (UL standard)
8	A9011WD	1	Power Supply Cord (VDE standard)
9	A9026WD	1	Power Supply Cord (SAA standard)
10	A9614KC	1	Connector
11	A9105KF	1	Fuse (10 A) } *2

(select)

Note


*1: Located in the fuse holder, see pages 10 & 11 item 13

*2: Model 3750 □□ - □□ .../DC (option)


Spares

Note*2 : Z-fold Chart is supplied in packs of 6 sheaves.
(One pack is the minimum order quantity.)

Parts No.	Order Q'ty	Description
B9855AY	6 units (1 pc. /unit)	20 m (10 mm div. on time axis)



Rack Mounting



Code	Item	Part Name	Qty	Description
379811	1	Rack Adapter	2	JIS
	2	Plate	2	
379813	3	B. H. Screw M4 × 8	4	ANSI

- (1) All rights reserved. No part of this manual may be reproduced in any form without YOKOGAWA's written permission.
- (2) The contents of this manual are subject to change without notice.
- (3) The above notwithstanding, YOKOGAWA can assume no responsibility for any errors in this manual or their consequences.